

Monthly Overflow Report

Date Range: August, 2020

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

000	WLS074E117	08/09/20	08/09/20	5 hours	0.00001		Grit/Debris	1328 Georgetown Dr - Cleaned Line
000	10816023	08/27/20	08/27/20	3 hours	0.00001	0.98	Grit/Debris	1517 Watercress Dr - Cleaned Line
000	09213056	08/29/20	08/29/20	3 hours	0.00001	1.24	Grit/Debris	3515 Park Ave - Cleaned Line
134	Riverside Drive PS	08/13/20	08/13/20	0.2 hours	0.01	2.06	VFD or Soft Start	Soft starts failed to reset after power failure.

Monthly Overflow Report

Date Range: August, 2020

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	06014001	08/13/20	08/13/20	1 hours	0.0001		Grit/Debris	1993 Southerland Dr - Cleaned Line
000	10316058	08/28/20	08/28/20	3.5 hours	0.0001	0.92	Grit/Debris	4202 Harding Pk - Cleaned Line
000	06014001	08/31/20	08/31/20	4 hours	0.00001	1.27	Grit/Debris	1991 Southerland Dr - Cleaned Line