

# Monthly Overflow Report

Date Range: August, 2022

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
000	09203133	08/02/22	1 hours		Grit/Debris	2211 Meharry Blvd - Cleaned Line
		08/02/22	0.00001	Dry Weather Release	Contained, did not reach water	28th Avenue SPS
000	13413094	08/03/22	8 hours		Roots	281 Paragon Mills Rd - Cleaned Line
		08/03/22	0.00001	Dry Weather Release	Contained, did not reach water	Browns Creek SPS
000	07109002	08/04/22	0.5 hours		Grease	1501 Baptist World Center Dr - Cleaned Line
		08/04/22	0.0001	Dry Weather Overflow	Pages Branch	Cowan Street SPS
000	09210052	08/15/22	2 hours		Grit/Debris	501 28th Ave N - Cleaned Line
		08/15/22	0.00001	Dry Weather Release	Contained, did not reach water	Central WWTP
000	08601125	08/18/22	2 hours		Grit/Debris	3441 Lebanon Pk - Cleaned Line
		08/18/22	0.0001	Dry Weather Release	Contained, did not reach water	Dodson Chapel SPS
000	15007072	08/21/22	0.1 hours		Grit/Debris	3156 Country Meadow Rd - Cleaned Line
		08/21/22	0.00001	Dry Weather Release	Contained, did not reach water	Smith Springs SPS
000	08603182	08/22/22	1 hours		Grit/Debris	529 Old Lebanon Dirt Rd - Cleaned Line
		08/22/22	0.0001	Dry Weather Release	Contained, did not reach water	Dodson Chapel SPS
000	07207120	08/24/22	1 hours		Grit/Debris	1150 Kirkland Ave - Cleaned Line
		08/24/22	0.00005	Dry Weather Release	Contained, did not reach water	Shelby Park SPS
000	10713069	08/29/22	1.5 hours	0.07	Grit/Debris	309 Philfre Ct - Cleaned Line
		08/29/22	0.0001	Wet Weather Overflow	Mill Creek	Browns Creek SPS
000	13516073	08/30/22	4 hours	0.01	Other/not listed	408 Flintlock Ct - Cleaned MH, doghouse not cut out
		08/30/22	0.0001	Wet Weather Release	Contained, did not reach water	Smith Springs SPS

Monthly Totals: # of Events and Gallons					12 Month Rolling Totals: # of Events and Gallons						
<b>Dry Weather Releases:</b>	7	290	<b>Wet Weather Releases:</b>	1	100	<b>Dry Weather Releases:</b>	31	2,510	<b>Wet Weather Releases:</b>	45	623,350
<b>Dry Weather Overflows:</b>	1	100	<b>Wet Weather Overflows:</b>	1	100	<b>Dry Weather Overflows:</b>	16	3,040	<b>Wet Weather Overflows:</b>	257	988,526,630

# Monthly Overflow Report

Date Range: August, 2022

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

## Sanitary Sewer Overflows and Releases

No Overflows or Releases											
Monthly Totals: # of Events and Gallons						12 Month Rolling Totals: # of Events and Gallons					
<b>Dry Weather Releases:</b>	0	0	<b>Wet Weather Releases:</b>	0	0	<b>Dry Weather Releases:</b>	3	700	<b>Wet Weather Releases:</b>	1	10
<b>Dry Weather Overflows:</b>	0	0	<b>Wet Weather Overflows:</b>	0	0	<b>Dry Weather Overflows:</b>	2	1,100	<b>Wet Weather Overflows:</b>	37	12,563,000

# Monthly Overflow Report

Date Range: August, 2022

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
<b>Sanitary Sewer Overflows and Releases</b>						
000	04915015	08/23/22	4 hours		Grit/Debris	0 Tisdall Dr - Cleaned Line
		08/23/22	0.0001	Dry Weather Overflow	Vhoins Branch	Whites Creek SPS
<b>Monthly Totals: # of Events and Gallons</b>				<b>12 Month Rolling Totals: # of Events and Gallons</b>		
<b>Dry Weather Releases:</b>	0	0	<b>Wet Weather Releases:</b>	0	0	<b>Dry Weather Releases:</b> 4 220 <b>Wet Weather Releases:</b> 18 1,302,590
<b>Dry Weather Overflows:</b>	1	100	<b>Wet Weather Overflows:</b>	0	0	<b>Dry Weather Overflows:</b> 6 110,230 <b>Wet Weather Overflows:</b> 55 20,460,100