

Monthly Overflow Report

Date Range: December, 2019

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	11907049	12/01/19	12/01/19	4 hours	0.001	1.13	Rainfall	716 Old Glenrose
000	10506045	12/04/19	12/04/19	4 hours	0.00001		Grit/Debris	1301 8th Ave S - Cleaned line
000	15010063	12/07/19	12/07/19	2 hours	0.0001		Grease	100 Stone Bridge Ct - Cleaned Line
000	15010066	12/07/19	12/07/19	2 hours	0.0001		Grease	100 Stone Bridge Ct - Cleaned Line
000	16006007	12/08/19	12/08/19	1 hours	0.0001		Grit/Debris	5248 Franklin Pike Cir - Cleaned Line
000	WMN033P078	12/11/19	12/11/19	4.5 hours	0.0001		Grit/Debris	2304 Brookfield Dr - Cleaned Line
000	07205047	12/12/19	12/12/19	4 hours	0.00001		Grit/Debris	1026 E Trinity Ln - Cleaned Line
000	11907146	12/16/19	12/17/19	16 hours	0.1	1.71	Rainfall	431 E Thompson Ln
000	08608149	12/23/19	12/24/19	22 hours	0.001		Grease	2205 Willesden Green - Cleaned Line
000	WMN058A016	12/26/19	12/27/19	21 hours	0.001		Grit/Debris	2339 Rocky Fork Rd - Cleaned Line
000	16313003	12/28/19	12/28/19	3 hours	0.03		Grease	5353 Cane Ridge Rd - Cleaned Line, Est. 150 GPM
000	11907146	12/30/19	12/31/19	26 hours	0.1	2.34	Rainfall	431 E Thompson Ln
000	11706063	12/30/19	12/30/19	2.5 hours	0.001		Grit/Debris	2164 Golf Club Ln - Cleaned Line
000	11907049	12/30/19	12/31/19	26 hours	0.15	2.34	Rainfall	765 Old Glenrose Ave - Est. 100 GPM
000	11907147	12/30/19	12/31/19	26 hours	0.001	2.34	Rainfall	0 Old Glenrose Ave
102	Smith Springs PS	12/01/19	12/01/19	12.83 hours	1.018	0.63	Rainfall	Infiltration/inflow. EQ full.
102	Smith Springs PS	12/29/19	12/30/19	15 hours	0.962	2.70	Rainfall	Infiltration/inflow. EQ full.
103	McCrary Creek PS	12/29/19	12/30/19	7.25 hours	0.802	2.74	Rainfall	Infiltration/inflow. Station at rated capacity.
125	Hopedale PS	12/29/19	12/29/19	2.5 hours	0.01	2.40	Rainfall	Infiltration/inflow. Station at rated capacity.
131	Hurricane Creek PS	12/29/19	12/30/19	6.5 hours	0.5	2.61	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	12/29/19	12/29/19	6.58 hours	1.15	2.17	Rainfall	Infiltration/inflow. Station at rated capacity.
163	Tillman SPS	12/29/19	12/30/19	12.15 hours	0.1	2.73	Rainfall	Infiltration/inflow. Station at rated capacity.
175	Baronswood Dr	12/16/19	12/16/19	2.5 hours	0.01	1.48	Controller	Controller failure.
186	Mt. View SPS	12/29/19	12/29/19	3 hours	0.02	2.73	Rainfall	Infiltration/inflow. Station at rated capacity.
187	Peppertree PS	12/29/19	12/30/19	4 hours	0.05	2.61	Rainfall	Infiltration/inflow. Station at rated capacity.
188	South Oak Hill PS	12/29/19	12/30/19	10 hours	0.6	2.19	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: December, 2019

189	Langford Farms PS	12/29/19	12/30/19	6 hours	0.06	2.14	Rainfall	Infiltration/inflow. Station at rated capacity.
190	Towne Village PS	12/29/19	12/30/19	8.75 hours	0.1	2.73	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	12/01/19	12/01/19	3.75 hours	0.033	1.66	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	12/16/19	12/17/19	17.17 hours	0.268	1.87	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	12/29/19	01/01/20	58.67 hours	5.133	2.74	Rainfall	Infiltration/inflow. Station at rated capacity.
226	Cowan St. Relief Bleeder	12/29/19	12/29/19	3.17 hours	0.113	2.26	Rainfall	Infiltration/inflow. Station at rated capacity.
384	501 Bismark Dr.	12/16/19	12/18/19	43 hours	1.3	1.87	Rainfall	501 Bismark Dr - Est. 500 GPM
384	501 Bismark Dr.	12/30/19	01/02/20	72 hours	2	2.78	Rainfall	501 Bismark - Est. 500 GPM

Monthly Overflow Report

Date Range: December, 2019

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05315021	12/30/19	12/31/19	15 hours	0.0001	2.52	Rainfall	118 Riner Ct
106	Vandiver PS	12/29/19	12/29/19	7 hours	0.315	2.52	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	12/29/19	12/29/19	2.33 hours	0.07	2.35	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	12/29/19	12/30/19	7.83 hours	1.383	2.35	Rainfall	Infiltration/inflow. Station at rated capacity.
150	Hidden Acres PS	12/15/19	12/15/19	3.5 hours	0.05	0.00	Air Relief Valve	Broken air relief valve
150	Hidden Acres PS	12/29/19	12/29/19	4.5 hours	0.4	2.40	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: December, 2019

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
107	West Park PS	12/29/19	12/29/19	3.42 hours	0.255	2.08	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	12/16/19	12/17/19	15.17 hours	0.84	1.22	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	12/29/19	12/30/19	17.58 hours	1.077	2.08	Rainfall	Infiltration/inflow. Station at rated capacity.
126	Cleeces Ferry PS	12/29/19	12/29/19	4.5 hours	0.1	2.21	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	12/16/19	12/16/19	14.8 hours	0.05	2.31	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	12/29/19	12/30/19	8.15 hours	0.03	2.86	Rainfall	Infiltration/inflow. Station at rated capacity.
217	516 Basswood Ave.	12/29/19	12/29/19	3.83 hours	0.061	2.08	Rainfall	516 Basswood Ave