

# Monthly Overflow Report

Date Range: December, 2023

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

## Sanitary Sewer Overflows and Releases

000	16206114	12/06/23	5 hours		Roots	221 Sterry Ct - Cleaned Line
		12/06/23	0.0001	Dry Weather Release	Contained, did not reach water	Browns Creek SPS
000	13413062	12/06/23	1.5 hours		Line Break	4810 Jeffery Dr - Repaired Line
		12/06/23	0.00001	Dry Weather Release	Contained, did not reach water	Browns Creek SPS
000	09515037	12/12/23	2 hours		Roots	26 Century Blvd - Cleaned Line (Sims Branch)
		12/12/23	0.0001	Dry Weather Overflow		Browns Creek SPS
000	17102038	12/13/23	23 hours		Roots	5914 Stone Brook Dr - Cleaned Line
		12/14/23	0.0005	Dry Weather Overflow	Seven Mile Creek	Brentwood Villa SPS
000	15109008	12/14/23	3 hours		Grease	4600 Derbyshire Dr - Cleaned Line
		12/14/23	0.00001	Dry Weather Release	Contained, did not reach water	Towne Village SPS
000	13413062	12/19/23	26 hours		Line Break	4810 Jeffery Dr - Repaired Line
		12/20/23	0.00001	Dry Weather Release	Contained, did not reach water	Browns Creek SPS
226	Cowan St. Relief Bleeder	12/01/23	3.08 hours	0.80	Other/not listed	Station shutdown due to plant construction work.
		12/01/23	0.005	Wet Weather Overflow	Cumberland River	Cowan Street SPS

Monthly Totals: # of Events and Gallons					12 Month Rolling Totals: # of Events and Gallons						
<b>Dry Weather Releases:</b>	4	130	<b>Wet Weather Releases:</b>	0	0	<b>Dry Weather Releases:</b>	25	2,170	<b>Wet Weather Releases:</b>	20	3,660
<b>Dry Weather Overflows:</b>	2	600	<b>Wet Weather Overflows:</b>	1	5,000	<b>Dry Weather Overflows:</b>	7	23,720	<b>Wet Weather Overflows:</b>	33	9,018,350

# Monthly Overflow Report

Date Range: December, 2023

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
<b>Sanitary Sewer Overflows and Releases</b>						
000	05201099	12/07/23	1 hours		Force Main	517 Forest Park Rd - Repaired FM
		12/07/23	0.001	Dry Weather Overflow	Gibson Creek	Gibson Creek SPS
000	03414023	12/14/23	23 hours		Grit/Debris	207 Welworth St - Cleaned Line
		12/15/23	0.0005	Dry Weather Overflow	Dry Creek	Dry Creek SPS
109	Dry Creek PS	12/09/23	13 hours	0.92	Power Related	Power outage related to Tornado.
		12/10/23	11	Wet Weather Overflow	Cumberland River	Dry Creek SPS
<b>Monthly Totals: # of Events and Gallons</b>				<b>12 Month Rolling Totals: # of Events and Gallons</b>		
<b>Dry Weather Releases:</b>	0	0	<b>Wet Weather Releases:</b>	0	0	<b>Dry Weather Releases:</b> 1 150,000 <b>Wet Weather Releases:</b> 2 20
<b>Dry Weather Overflows:</b>	2	1,500	<b>Wet Weather Overflows:</b>	1	11,000,000	<b>Dry Weather Overflows:</b> 4 6,510 <b>Wet Weather Overflows:</b> 10 13,281,100

# Monthly Overflow Report

Date Range: December, 2023

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

## Sanitary Sewer Overflows and Releases

000	10402060	12/06/23	2 hours	0.02	Grit/Debris	303 31st Ave N - Cleaned Line
		12/06/23	0.0001	Wet Weather Release	Contained, did not reach water	Central WWTP

Monthly Totals: # of Events and Gallons					12 Month Rolling Totals: # of Events and Gallons						
<b>Dry Weather Releases:</b>	0	0	<b>Wet Weather Releases:</b>	1	100	<b>Dry Weather Releases:</b>	8	1,340	<b>Wet Weather Releases:</b>	13	5,260
<b>Dry Weather Overflows:</b>	0	0	<b>Wet Weather Overflows:</b>	0	0	<b>Dry Weather Overflows:</b>	2	20,010	<b>Wet Weather Overflows:</b>	16	9,046,130