

Monthly Overflow Report

Date Range: February, 2020

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	11907146	02/06/20	02/06/20	12 hours	0.2	0.94	Rainfall	431 E Thompson Ln - Est 300 GPM
000	13308081	02/08/20	02/08/20	4 hours	0.02		Grease	837 Reischa Ct - Cleaned Line
000	11907146	02/10/20	02/12/20	45 hours	0.8	2.13	Rainfall	431 E Thompson Ln - Est 300 GPM
000	13406002	02/12/20	02/13/20	24 hours	0.001	1.60	Rainfall	520 Harding Industrial Dr
000	06115006	02/12/20	02/12/20	2 hours	0.00001	1.60	Grit/Debris	3919 Baxter Ave - Cleaned Line
000	13406027	02/12/20	02/13/20	8 hours	0.001	1.60	Rainfall	520 Harding Industrial Dr
000	10612023	02/12/20	02/13/20	17 hours	0.001	1.75	Rainfall	0 Murfreesboro Pk
000	13412030	02/12/20	02/13/20	8 hours	0.001	1.60	Rainfall	5135 Harding Pl
000	11904005	02/12/20	02/13/20	17 hours	0.001	1.75	Rainfall	321 Wimpole Dr
000	10616020	02/12/20	02/13/20	10 hours	0.001	1.75	Rainfall	1001 Murfreesboro Pk
000	13412031	02/12/20	02/13/20	8 hours	0.001	1.60	Rainfall	5135 Harding Pl
000	1340627B	02/12/20	02/13/20	24 hours	0.001	1.60	Rainfall	520 Harding Industrial Dr
000	13406029	02/12/20	02/13/20	8 hours	0.001	1.60	Rainfall	432 Harding Industrial Dr
000	13407009	02/12/20	02/13/20	8 hours	0.001	1.60	Rainfall	0 Murfreesboro Pk
000	13407010	02/12/20	02/13/20	8 hours	0.001	1.60	Rainfall	0 Murfreesboro Pk
000	13407003	02/12/20	02/13/20	24 hours	0.001	1.60	Rainfall	0 Knight Valley Dr
000	12013049	02/12/20	02/13/20	24 hours	0.001	1.60	Rainfall	917 Currey Dr
000	10616013	02/12/20	02/13/20	17 hours	0.001	1.75	Rainfall	993 Murfreesboro Pk
000	11907146	02/12/20	02/15/20	66 hours	1.2	1.75	Rainfall	431 E Thompson Ln - Est 300 GPM
000	11908024	02/12/20	02/13/20	24 hours	0.001	1.75	Rainfall	992 E Thompson Ln
000	11907147	02/13/20	02/14/20	34 hours	0.6	1.75	Rainfall	0 Glenrose Ave - Est 300 GPM
000	08602059	02/13/20	02/14/20	28 hours	0.04	1.76	Rainfall	428 Old Lebanon Dirt Rd - Est 25 GPM
000	08602060	02/13/20	02/14/20	22 hours	0.06	1.76	Rainfall	428 Old Lebanon Dirt Rd - Est 50 GPM
000	08602057	02/13/20	02/14/20	28 hours	0.04	1.76	Rainfall	428 Old Lebanon Dirt Rd - Est 25 GPM
000	08602099	02/13/20	02/14/20	28 hours	0.5	1.76	Rainfall	389 Old Lebanon Dirt Rd - Est 300 GPM
000	08603013	02/13/20	02/14/20	22 hours	0.03	1.76	Rainfall	428 Old Lebanon Dirt Rd - Est 25 GPM

Monthly Overflow Report

Date Range: February, 2020

000	08603180	02/13/20	02/14/20	27.5 hours	0.001	1.76	Rainfall	4124 Andrew Jackson Pky
000	10507063	02/14/20	02/14/20	2 hours	0.00001		Grit/Debris	1307 Pillow St - Cleaned Line
000	10505140	02/16/20	02/16/20	1 hours	0.00001		Grit/Debris	1114 Wade Ave - Cleaned Line
000	08216010	02/19/20	02/21/20	45 hours	0.00001		Line Break	700 Main St - Repaired Line
000	07311033	02/22/20	02/22/20	1.5 hours	0.001		Grit/Debris	2405 Fairbrook Dr - Cleaned Line
000	16108065	02/28/20	02/28/20	2 hours	0.0001		Grease	500 Ocala Dr - Cleaned Line
102	Smith Springs PS	02/05/20	02/05/20	2.5 hours	0.047	1.69	Rainfall	Infiltration/inflow. EQ full.
102	Smith Springs PS	02/11/20	02/11/20	5.25 hours	0.39	1.80	Rainfall	Infiltration/inflow. EQ full.
102	Smith Springs PS	02/12/20	02/16/20	86.75 hours	1.77	1.91	Rainfall	Infiltration/inflow. EQ full.
103	McCrary Creek PS	02/11/20	02/11/20	3.5 hours	0.031	1.90	Rainfall	Infiltration/inflow. Station at rated capacity.
103	McCrary Creek PS	02/12/20	02/13/20	24 hours	0.262	1.76	Rainfall	Infiltration/inflow. Station at rated capacity.
131	Hurricane Creek PS	02/13/20	02/13/20	11 hours	0.7	2.09	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	02/12/20	02/13/20	8.75 hours	0.2	1.51	Rainfall	Infiltration/inflow. Station at rated capacity.
176	Dodson Chapel PS	02/12/20	02/14/20	42.67 hours	5.491	3.66	Rainfall	Infiltration/inflow. Station at rated capacity.
188	South Oak Hill PS	02/11/20	02/11/20	6.75 hours	0.4	1.89	Rainfall	Infiltration/inflow. Station at rated capacity.
188	South Oak Hill PS	02/12/20	02/13/20	16 hours	1	2.31	Rainfall	Infiltration/inflow. Station at rated capacity.
190	Towne Village PS	02/13/20	02/13/20	3 hours	0.05	1.91	Rainfall	Infiltration/inflow. Station at rated capacity.
384	501 Bismark Dr.	02/05/20	02/05/20	18 hours	0.5	1.47	Rainfall	501 Bismark Dr - Est 500 GPM
384	501 Bismark Dr.	02/10/20	02/17/20	168 hours	5	3.34	Rainfall	501 Bismark Dr - Est 500 GPM

Monthly Overflow Report

Date Range: February, 2020

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

106	Vandiver PS	02/12/20	02/13/20	12.5 hours	0.261	3.44	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	02/10/20	02/11/20	11.09 hours	0.451	1.68	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	02/12/20	02/13/20	19.08 hours	0.785	1.49	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: February, 2020

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	10402036	02/02/20	02/02/20	1 hours	0.0001		Grit/Debris	3127 Long Blvd - Cleaned Line
000	11616040	02/10/20	02/10/20	1 hours	0.0001	1.14	Rainfall	4012 Wallace Ln
000	11616040	02/11/20	02/11/20	11 hours	0.0001	0.71	Rainfall	4012 Wallace Ln
000	10301017	02/12/20	02/12/20	2 hours	0.0001	1.35	Grease	6211 Charlotte Pk - Cleaned Line
000	06001013	02/13/20	02/14/20	37 hours	0.1	1.60	Rainfall	3258 Brick Church Pk - Est 50 GPM
000	10203073	02/13/20	02/13/20	4 hours	0.001	1.54	Force Main	431 Capri Dr - Repaired FM
000	05911027	02/13/20	02/14/20	39 hours	0.2	1.51	Rainfall	701 Rowan Dr - Est 100 GPM
000	04816011	02/15/20	02/15/20	2 hours	0.00001		Grit/Debris	3836 Stevens Ln - Cleaned Line
000	14409005	02/19/20	02/19/20	2 hours	0.00001		Grit/Debris	4362 Chickering Ln - Cleaned Line
000	14409005	02/20/20	02/20/20	2.5 hours	0.0001		Grit/Debris	4362 Chickering Ln - Cleaned Line
000	14409005	02/23/20	02/23/20	4 hours	0.00001		Grit/Debris	4362 Chickering Ln - Cleaned Line
000	04914029	02/23/20	02/23/20	3 hours	0.001		Grit/Debris	577 Green Ln - Cleaned Line
000	09114082	02/24/20	02/24/20	1 hours	0.00001		Grease	5815 Charlotte Pk - Cleaned Line
114	Davidson Branch PS	02/05/20	02/06/20	8 hours	0.174	1.70	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	02/10/20	02/11/20	24.91 hours	0.347	1.56	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	02/12/20	02/13/20	13.33 hours	0.246	1.54	Rainfall	Infiltration/inflow. Station at rated capacity.
126	Cleeces Ferry PS	02/13/20	02/14/20	36 hours	0.7	1.54	Force Main	Broken force main.
145	Joelton PS	02/12/20	02/13/20	5 hours	0.02	1.34	Rainfall	Infiltration/inflow. Station operating normally.