

Monthly Overflow Report

Date Range: February, 2023

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	16408090	02/01/23	5 hours	0.39	Grit/Debris	0 Hamilton Church Rd - Cleaned Line
		02/01/23	0.0001	Wet Weather Release	Contained, did not reach water	South Shores SPS
000	07113018	02/11/23	2.5 hours		Grit/Debris	115 Great Circle Rd - Cleaned Line
		02/11/23	0.00001	Dry Weather Release	Contained, did not reach water	Metro Center SPS
000	09308057	02/14/23	1 hours	0.04	Grit/Debris	501 Crutcher St - Cleaned Line
		02/14/23	0.00001	Wet Weather Release	Contained, did not reach water	Central WWTP
000	13112009	02/16/23	13 hours	2.04	Rainfall	1108 Battery Ln
		02/16/23	0.001	Wet Weather Overflow	Browns Creek	Browns Creek SPS
000	13112013	02/16/23	13 hours	2.04	Rainfall	4417 Scenic Dr
		02/16/23	0.001	Wet Weather Overflow	Browns Creek	Browns Creek SPS
000	WMN059B027	02/17/23	1 hours	1.72	Grit/Debris	179 Lodge Hall Rd - Cleaned Line
		02/17/23	0.00001	Wet Weather Overflow	Mill Creek	Bent Creek SPS
000	13316045	02/23/23	3 hours	0.03	Grit/Debris	293 Garry Dr - Cleaned Line
		02/23/23	0.00001	Wet Weather Release	Contained, did not reach water	Browns Creek SPS
000	08603025	02/28/23	1.5 hours		Grit/Debris	1001 Carriage Way Ct - Cleaned Line
		02/28/23	0.00001	Dry Weather Release	Contained, did not reach water	Dodson Chapel SPS
222	149 Barker Road	02/16/23	12.33 hours	2.20	Rainfall	Infiltration/inflow. Station operating normally.
		02/17/23	0.29	Wet Weather Overflow	Cumberland River	Barker Road SPS
384	501 Bismark Dr.	02/16/23	34 hours	1.90	Rainfall	501 Bismark Dr
		02/17/23	1	Wet Weather Overflow	Mill Creek	Browns Creek SPS
Monthly Totals: # of Events and Gallons				12 Month Rolling Totals: # of Events and Gallons		
Dry Weather Releases:	2	20	Wet Weather Releases:	3	120	Dry Weather Releases: 39 15,025 Wet Weather Releases: 31 14,210
Dry Weather Overflows:	0	0	Wet Weather Overflows:	5	1,292,010	Dry Weather Overflows: 13 1,030,430 Wet Weather Overflows: 196 588,498,860

Monthly Overflow Report

Date Range: February, 2023

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

Sanitary Sewer Overflows and Releases

000	04312035	02/19/23	2 hours		Grit/Debris	218 Rio Vista Dr - Cleaned Line
		02/19/23	0.00001	Dry Weather Overflow	Cumberland River	Vandiver SPS
Monthly Totals: # of Events and Gallons					12 Month Rolling Totals: # of Events and Gallons	
Dry Weather Releases:	0	0	Wet Weather Releases:	0	0	Dry Weather Releases: 3 610 Wet Weather Releases: 1 10
Dry Weather Overflows:	1	10	Wet Weather Overflows:	0	0	Dry Weather Overflows: 3 1,110 Wet Weather Overflows: 15 13,995,000

Monthly Overflow Report

Date Range: February, 2023

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	10213029	02/09/23	2.5 hours	0.46	Grit/Debris	7050 Charlotte Pk - Cleaned Line
		02/09/23	0.00001	Wet Weather Release	Contained, did not reach water	Davidson Branch SPS
000	06001009	02/16/23	14 hours	1.74	Rainfall	3258 Brick Church Pk
		02/16/23	0.001	Wet Weather Release	Contained, did not reach water	Whites Creek SPS
000	07001028	02/16/23	8 hours	1.74	Grit/Debris	2899 Tucker Rd - Cleaned Line
		02/16/23	0.00001	Wet Weather Overflow	Whites Creek	Whites Creek SPS
000	10408074	02/22/23	8 hours	0.13	Grit/Debris	1225 Villa Pl alley - Cleaned Line
		02/23/23	0.00001	Wet Weather Release	Contained, did not reach water	Central WWTP
000	02916003	02/22/23	0.5 hours	0.49	Grit/Debris	5568 Clarksville Pk - Cleaned Line
		02/22/23	0.0001	Wet Weather Overflow	Little Marrowbone Creek	Germantown SPS
000	09102078	02/23/23	2 hours	0.18	Grit/Debris	5507 Centennial Blvd - Cleaned Line
		02/23/23	0.00001	Wet Weather Release	Contained, did not reach water	West Park SPS
114	Davidson Branch PS	02/16/23	39.16 hours	1.79	Rainfall	Infiltration/inflow. Station operating normally.
		02/17/23	2.192	Wet Weather Overflow	Cumberland River	Davidson Branch SPS
Monthly Totals: # of Events and Gallons				12 Month Rolling Totals: # of Events and Gallons		
Dry Weather Releases:	0	0	Wet Weather Releases:	4	1,030	Dry Weather Releases: 4 40 Wet Weather Releases: 17 305,200
Dry Weather Overflows:	0	0	Wet Weather Overflows:	3	2,192,110	Dry Weather Overflows: 6 1,230 Wet Weather Overflows: 32 11,120,130