

Monthly Overflow Report

Date Range: February, 2024

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date End Date	Duration (hrs) Volume (mg)	Rainfall Overflow Type	Overflow Cause Receiving Stream	Remarks Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	17502099	02/01/24 02/01/24	3.5 hours 0.00002		Grease Dry Weather Release	2128 Preserve Cir Preserves at Old Hickory SPS
000	08612122	02/02/24 02/03/24	28 hours 0.0001		Grit/Debris Dry Weather Release	4948 Myra Dr Dodson Chapel SPS
000	07310019	02/05/24 02/05/24	2 hours 0.00001		Grit/Debris Dry Weather Release	3720 Moss Rose Dr Shelby Park SPS
000	WMN33P57	02/05/24 02/06/24	28 hours 0.0001		Roots Dry Weather Release	2476 Titans Ln Browns Creek SPS
000	16210102	02/07/24 02/07/24	8.5 hours 0.00001		Roots Dry Weather Release	109 Bess Ct S Browns Creek SPS
000	08616029	02/08/24 02/08/24	2 hours 0.0001		Grit/Debris Dry Weather Release	1412 Central Ct Dodson Chapel SPS
000	08613007	02/11/24 02/12/24	6.5 hours 0.00001	2.63	Force Main Wet Weather Release	2080 Elk Springs Dr Villages of Riverwood SPS
000	11907144	02/11/24 02/11/24	0.5 hours 0.001	1.26	Rainfall Wet Weather Overflow	765 Old Glenrose Ave Browns Creek SPS
000	11907049	02/11/24 02/11/24	11 hours 0.07	1.26	Rainfall Wet Weather Overflow	765 Old Glenrose Ave Browns Creek SPS
000	10616031	02/11/24 02/11/24	19 hours 0.11	1.26	Rainfall Wet Weather Overflow	305 Millwood Dr Browns Creek SPS
000	11907049	02/12/24 02/13/24	28 hours 0.17	1.58	Rainfall Wet Weather Overflow	765 Old Glenrose Ave Browns Creek SPS
000	11907144	02/12/24 02/13/24	26 hours 0.16	1.58	Rainfall Wet Weather Overflow	765 Old Glenrose Ave Browns Creek SPS
000	10616031	02/12/24 02/14/24	31 hours 0.19	1.58	Rainfall Wet Weather Overflow	305 Millwood Dr Browns Creek SPS
000	09613079	02/13/24 02/15/24	39 hours 0.0001	0.01	Line Break Wet Weather Release	504 Donelson Pk Browns Creek SPS

Monthly Overflow Report

Date Range: February, 2024

000	08303022	02/15/24	22 hours	0.50	Line Break	1298 Porter Rd									
		02/16/24	0.00001	Wet Weather Release	Contained, did not reach water	Browns Creek SPS									
000	WMN56G14	02/24/24	5.5 hours		Force Main	1646 Sunset Rd									
		02/25/24	0.0001	Dry Weather Release	Contained, did not reach water	Browns Creek SPS									
000	17203091	02/26/24	5 hours		Grease	5337 Windypine Dr									
		02/26/24	0.0001	Dry Weather Overflow	Seven Mile Creek	Browns Creek SPS									
000	11902063	02/26/24	5 hours		Grit/Debris	98 Peachtree St									
		02/26/24	0.0001	Dry Weather Release	Contained, did not reach water	Browns Creek SPS									
000	08513014	02/27/24	1.5 hours		Grit/Debris	231 Cliffdale Rd									
		02/27/24	0.0001	Dry Weather Overflow	Stones River	Donelson Plaza SPS									
000	13511026	02/29/24	2 hours		Grease	600 Long Hunter Ln									
		02/29/24	0.00001	Dry Weather Release	Contained, did not reach water	Smith Springs SPS									
134	Riverside Drive PS	02/12/24	8.5 hours	1.67	Rainfall	Infiltration/inflow. Station operating normally.									
		02/13/24	0.138	Wet Weather Overflow	Cumberland River	Riverside Drive SPS									
176	Dodson Chapel PS	02/13/24	3.08 hours	1.48	Rainfall	Infiltration/inflow. Station operating normally. EQ full									
		02/14/24	0.355	Wet Weather Overflow	Stoners Creek	Dodson Chapel SPS									
222	149 Barker Road	02/11/24	0.58 hours	1.40	Rainfall	Infiltration/inflow. Station operating normally.									
		02/11/24	0.01	Wet Weather Overflow	Cumberland River	Barker Road SPS									
222	149 Barker Road	02/12/24	23.5 hours	1.24	Rainfall	Infiltration/inflow. Station operating normally.									
		02/13/24	2.199	Wet Weather Overflow	Cumberland River	Barker Road SPS									
384	501 Bismark Dr.	02/11/24	21 hours	1.26	Rainfall	501 Bismark Dr									
		02/11/24	0.4	Wet Weather Overflow	Mill Creek	Browns Creek SPS									
384	501 Bismark Dr.	02/12/24	38 hours	1.53	Rainfall	501 Bismark Dr									
		02/14/24	1	Wet Weather Overflow	Mill Creek	Browns Creek SPS									
Monthly Totals: # of Events and Gallons						12 Month Rolling Totals: # of Events and Gallons									
Dry Weather Releases:		9	550	Wet Weather Releases:		3	120	Dry Weather Releases:		32	11,700	Wet Weather Releases:		19	2,660
Dry Weather Overflows:		2	200	Wet Weather Overflows:		12	4,803,000	Dry Weather Overflows:		11	22,220	Wet Weather Overflows:		38	10,929,620

Monthly Overflow Report

Date Range: February, 2024

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

Sanitary Sewer Overflows and Releases

150	Hidden Acres PS	02/12/24	18 hours	1.52	Rainfall	Infiltration/inflow. Station operating normally.
		02/13/24	0.8	Wet Weather Overflow	Cumberland River	Hidden Acres SPS
Monthly Totals: # of Events and Gallons				12 Month Rolling Totals: # of Events and Gallons		
Dry Weather Releases:	0	0	Wet Weather Releases:	0	0	Dry Weather Releases: 2 150,100 Wet Weather Releases: 1 10
Dry Weather Overflows:	0	0	Wet Weather Overflows:	1	800,000	Dry Weather Overflows: 3 6,500 Wet Weather Overflows: 7 13,074,100

Monthly Overflow Report

Date Range: February, 2024

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	06001013	02/12/24	4 hours	1.46	Rainfall	3258 Brick Church Pk
		02/13/24	0.0001	Wet Weather Release	Contained, did not reach water	Whites Creek SPS
000	05911027	02/12/24	9.5 hours	1.53	Rainfall	700 Rowan Dr
		02/13/24	0.0001	Wet Weather Release	Contained, did not reach water	Whites Creek SPS
000	12911004	02/12/24	2 hours	1.41	Grit/Debris	0 Carnavon Pkwy
		02/12/24	0.0001	Wet Weather Release	Contained, did not reach water	West Park SPS
000	09004005	02/13/24	39 hours		Rainfall	6601 Centennial Blvd
		02/14/24	0.23	Dry Weather Overflow	Richland Creek	West Park SPS
000	11616061	02/21/24	3.5 hours		Grit/Debris	4016 Estes Rd
		02/21/24	0.00001	Dry Weather Release	Contained, did not reach water	West Park SPS
000	14513063	02/28/24	6.5 hours	0.97	Grit/Debris	1604 Otter Creek Rd
		02/28/24	0.0001	Wet Weather Release	Contained, did not reach water	Brentwood SPS
107	West Park PS	02/13/24	3.25 hours	1.51	Rainfall	Infiltration/inflow. EQ full
		02/13/24	0.279	Wet Weather Overflow	Richland Creek	West Park SPS
217	516 Basswood Ave.	02/12/24	6.17 hours	1.51	Rainfall	516 Basswood Ave
		02/13/24	0.027	Wet Weather Overflow	Cumberland River	West Park SPS
Monthly Totals: # of Events and Gallons				12 Month Rolling Totals: # of Events and Gallons		
Dry Weather Releases:	1	10	Wet Weather Releases:	4	400	Dry Weather Releases: 9 1,350 Wet Weather Releases: 10 730
Dry Weather Overflows:	1	230,000	Wet Weather Overflows:	2	306,000	Dry Weather Overflows: 3 250,010 Wet Weather Overflows: 8 4,124,010