

Monthly Overflow Report

Date Range: January, 2020

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	11907146	01/03/20	01/04/20	31 hours	0.6	1.66	Rainfall	431 E Thompson Ln - Est 300 GPM
000	11904005	01/03/20	01/04/20	31 hours	0.2	1.66	Rainfall	321 Wimpole Dr - Est 100 GPM
000	11909123	01/04/20	01/04/20	1 hours	0.0001	1.66	Grit/Debris	2849 Logan St - Cleaned Line
000	16112053	01/07/20	01/07/20	4 hours	0.0001		Grease	5560 Nolensville Rd - Cleaned Line
000	11909113	01/11/20	01/12/20	28 hours	0.001	1.75	Rainfall	2803 Foster Ave
000	14810001	01/21/20	01/22/20	2.5 hours	0.0001		Grease	3939 Apache Tr - Cleaned Line
000	14801043	01/23/20	01/24/20	20 hours	0.0001	0.88	Grit/Debris	3709 Turley Dr - Cleaned Line
000	13204037	01/27/20	01/27/20	1 hours	0.0001		Grease	2960 Armory Dr - Cleaned Line
102	Smith Springs PS	01/11/20	01/12/20	1.58 hours	0.024	1.64	Rainfall	Infiltration/inflow. Station at rated capacity. Eqs full.
103	McCrary Creek PS	01/11/20	01/11/20	5.92 hours	0.053	1.78	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	01/11/20	01/11/20	7.25 hours	0.2	1.85	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	01/11/20	01/11/20	8.42 hours	1.804	1.85	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	01/14/20	01/14/20	2.75 hours	0.105	1.17	Rainfall	Infiltration/inflow. Station at rated capacity.
188	South Oak Hill PS	01/11/20	01/11/20	7.5 hours	0.5	2.16	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	01/02/20	01/05/20	62.17 hours	6.025	1.92	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	01/11/20	01/13/20	28.42 hours	1.013	1.78	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	01/14/20	01/15/20	19.17 hours	0.861	1.46	Rainfall	Infiltration/inflow. Station at rated capacity.
226	Cowan St. Relief Bleeder	01/11/20	01/11/20	2.42 hours	0.059	1.84	Rainfall	Infiltration/inflow. Station at rated capacity.
384	501 Bismark Dr.	01/02/20	01/03/20	52 hours	1.5	1.64	Rainfall	501 Bismark - Est. 500 GPM
384	501 Bismark Dr.	01/11/20	01/12/20	29 hours	0.8	1.64	Rainfall	501 Bismark Dr - Est 500 GPM
384	501 Bismark Dr.	01/14/20	01/15/20	24 hours	0.7	1.14	Rainfall	501 Bismark Dr - Est 500 GPM

Monthly Overflow Report

Date Range: January, 2020

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04311068	01/10/20	01/10/20	2 hours	0.001		Grit/Debris	1040 N Dupont Ave - Cleaned Line
000	01203001	01/23/20	01/24/20	24 hours	0.0001		Force Main	Springfield Hwy - FM repaired (damaged by sign post)
000	01215001	01/25/20	01/29/20	98 hours	0.001		Force Main	0 Springfield Hwy - Repaired FM (intermittent seep)
106	Vandiver PS	01/11/20	01/11/20	2.75 hours	0.028	1.75	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	01/11/20	01/11/20	0.58 hours	0.001	1.76	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	01/11/20	01/12/20	10.17 hours	1.086	1.79	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: January, 2020

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05911027	01/03/20	01/04/20	23 hours	0.07	2.03	Rainfall	701 Rowan Dr - Est 50 GPM
000	07009031	01/06/20	01/06/20	6 hours	0.0001		Roots	3216 Curtis St - Cleaned Line
000	05915017	01/11/20	01/12/20	27 hours	0.08	1.88	Rainfall	3812 Cravath Dr - Est 50 GPM
000	11616040	01/11/20	01/12/20	16 hours	0.0001	1.85	Rainfall	4012 Wallace Ln
000	05911027	01/11/20	01/12/20	26 hours	0.08	1.88	Rainfall	701 Rowan Dr - Est 50 GPM
000	11616040	01/14/20	01/14/20	8 hours	0.0001	0.98	Rainfall	4012 Wallace Ln
107	West Park PS	01/11/20	01/11/20	2.67 hours	0.197	1.76	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	01/02/20	01/04/20	32.33 hours	0.661	1.74	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	01/11/20	01/12/20	14.42 hours	0.808	1.76	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	01/14/20	01/14/20	8.75 hours	0.155	1.29	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	01/03/20	01/03/20	4.1 hours	0.01	1.89	Rainfall	Infiltration/inflow. Station operating normally.
145	Joelton PS	01/11/20	01/11/20	5 hours	0.02	2.06	Rainfall	Infiltration/inflow. Station operating normally.
217	516 Basswood Ave.	01/11/20	01/11/20	3.08 hours	0.037	1.76	Rainfall	516 Basswood Ave