

# Monthly Overflow Report

Date Range: January, 2024

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
<b>Sanitary Sewer Overflows and Releases</b>						
000	16203071	01/04/24	3 hours		Roots	104 Panamint Dr - Cleaned Line
		01/04/24	0.0002	Dry Weather Overflow	Mill Creek	Browns Creek SPS
000	16303023	01/09/24	6 hours	0.98	Grit/Debris	727 Bell Rd - Cleaned Line
		01/09/24	0.001	Wet Weather Overflow	Mill Creek	Browns Creek SPS
000	10612023	01/12/24	4 hours	1.11	Rainfall	305 Millwood Dr
		01/12/24	0.018	Wet Weather Overflow	Mill Creek	Browns Creek SPS
000	10807019	01/22/24	1 hours		Grit/Debris	3108 Elm Hill Pk - Cleaned Line
		01/22/24	0.0001	Dry Weather Overflow	McCrory Creek	McCrory Creek SPS
000	10501180	01/23/24	44.5 hours	1.31	Other/not listed	1216 Edgehill Ave - Repaired Line (utility pole)
		01/25/24	0.00001	Wet Weather Overflow		Central WWTP
000	11907144	01/25/24	6 hours	1.31	Rainfall	765 Old Glenrose Ave
		01/26/24	0.001	Wet Weather Overflow	Mill Creek	Browns Creek SPS
000	11907049	01/25/24	11 hours	1.31	Rainfall	765 Old Glenrose Ave
		01/26/24	0.0005	Wet Weather Overflow	Mill Creek	Browns Creek SPS
000	10616031	01/25/24	12.5 hours	1.31	Rainfall	305 Millwood Dr
		01/26/24	0.001	Wet Weather Overflow	Mill Creek	Browns Creek SPS
000	16206113	01/26/24	1 hours	1.36	Roots	213 Sterry Ct - Cleaned Line
		01/26/24	0.00001	Wet Weather Release	Contained, did not reach water	Browns Creek SPS
000	15009115	01/29/24	3.5 hours	0.02	Grit/Debris	617 Forest Pointe Pl - Cleaned Line (Hamilton Creek)
		01/30/24	0.001	Wet Weather Overflow		Smith Springs SPS
176	Dodson Chapel PS	01/26/24	2 hours		Air Relief Valve	Air relief inside EQ #2 station broke. Localized release.
		01/26/24	0.01	Dry Weather Release	Contained, did not reach water	Dodson Chapel SPS
222	149 Barker Road	01/25/24	5.58 hours	1.54	Rainfall	Infiltration/inflow. Station operating normally.
		01/25/24	0.374	Wet Weather Overflow	Cumberland River	Barker Road SPS
384	501 Bismark Dr.	01/12/24	7.5 hours	1.19	Rainfall	501 Bismark Dr - Est 200 GPM
		01/12/24	0.09	Wet Weather Overflow	Mill Creek	Browns Creek SPS
384	501 Bismark Dr.	01/25/24	25 hours	1.54	Rainfall	501 Bismark Dr
		01/26/24	0.75	Wet Weather Overflow	Mill Creek	Browns Creek SPS

---

# Monthly Overflow Report

Date Range: January, 2024

<i>Monthly Totals: # of Events and Gallons</i>				<i>12 Month Rolling Totals: # of Events and Gallons</i>							
<i>Dry Weather Releases:</i>	1	10,000	<i>Wet Weather Releases:</i>	1	10	<i>Dry Weather Releases:</i>	26	11,190	<i>Wet Weather Releases:</i>	19	2,660
<i>Dry Weather Overflows:</i>	2	300	<i>Wet Weather Overflows:</i>	10	1,236,510	<i>Dry Weather Overflows:</i>	8	2,020	<i>Wet Weather Overflows:</i>	31	7,418,630

# Monthly Overflow Report

Date Range: January, 2024

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

## Sanitary Sewer Overflows and Releases

000	00216001	01/30/24	1.5 hours		Other/not listed	112 East End Rd - Vandalism, Replaced Cap	
		01/30/24	0.0001	Dry Weather Release	Contained, did not reach water	Dry Creek WWTP	
150	Hidden Acres PS	01/25/24	3.5 hours	1.55	Rainfall	Infiltration/inflow. Station operating normally.	
		01/25/24	0.3	Wet Weather Overflow	Cumberland River	Hidden Acres SPS	
<b>Monthly Totals: # of Events and Gallons</b>				<b>12 Month Rolling Totals: # of Events and Gallons</b>			
<b>Dry Weather Releases:</b>	1	100	<b>Wet Weather Releases:</b>	0	0	<b>Dry Weather Releases:</b> 2 150,100	<b>Wet Weather Releases:</b> 1 10
<b>Dry Weather Overflows:</b>	0	0	<b>Wet Weather Overflows:</b>	1	300,000	<b>Dry Weather Overflows:</b> 4 6,510	<b>Wet Weather Overflows:</b> 6 12,274,100

# Monthly Overflow Report

Date Range: January, 2024

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

## Sanitary Sewer Overflows and Releases

000	12912008	01/08/24	1 hours	0.56	Roots	6311 Percy Dr - Cleaned Line
		01/08/24	0.00001	Wet Weather Overflow	Vaughns Gap Branch	West Park SPS
000	10407151	01/13/24	2 hours	1.25	Grit/Debris	2801 Belcourt Ave - Cleaned Line
		01/13/24	0.00001	Wet Weather Release	Contained, did not reach water	Central WWTP
000	04915003	01/27/24	1 hours	0.47	Other/not listed	3410 Knight Dr - Repaired Line (utility pole)
		01/27/24	0.0001	Wet Weather Release	Contained, did not reach water	Whites Creek SPS

Monthly Totals: # of Events and Gallons					12 Month Rolling Totals: # of Events and Gallons						
<b>Dry Weather Releases:</b>	0	0	<b>Wet Weather Releases:</b>	2	110	<b>Dry Weather Releases:</b>	8	1,340	<b>Wet Weather Releases:</b>	10	1,360
<b>Dry Weather Overflows:</b>	0	0	<b>Wet Weather Overflows:</b>	1	10	<b>Dry Weather Overflows:</b>	2	20,010	<b>Wet Weather Overflows:</b>	9	6,010,120