

# Monthly Overflow Report

Date Range: June, 2020

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	07015031	06/01/20	06/01/20	1.5 hours	0.00001		Grease	2333 Rosa L Parks Blvd - Cleaned Line
000	17308011	06/02/20	06/02/20	1 hours	0.0001		Grit/Debris	5501 Blue Hole Rd - Cleaned Line
000	14803069	06/03/20	06/04/20	22 hours	0.001	0.10	Line Break	3240 Franklin Limestone Rd - Repaired Line
000	16112029	06/06/20	06/06/20	1 hours	0.00001		Grease	5753 Nolensville Pk - Cleaned Line
000	13107065	06/08/20	06/09/20	18 hours	0.0001	0.12	Grit/Debris	1203 Lone Oak Rd - Cleaned Line
000	16302006	06/14/20	06/14/20	2 hours	0.00001		Grit/Debris	4328 Winton Dr - Cleaned Line
000	08504057	06/17/20	06/17/20	4 hours	0.0001		Grit/Debris	5125 Mountainbrook Cir - Cleaned Line
000	09713009	06/23/20	06/23/20	1 hours	0.00001		Grit/Debris	3121 Blackwood Dr - Cleaned Line
000	16307004	06/29/20	06/29/20	1 hours	0.0001		Grit/Debris	149 Hickory Hollow Ter - Cleaned Line

---

# Monthly Overflow Report

Date Range: June, 2020

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

## Sanitary Sewer Overflows

000	05202001	06/17/20	06/17/20	4.5 hours	0.2		Force Main	712 Neelys Bend Rd - Repaired FM
000	02616016	06/19/20	06/19/20	2 hours	0.00001		Grit/Debris	2449 Mansker Dr - Cleaned Line