

Monthly Overflow Report

Date Range: June, 2021

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	18003068	06/03/21	4 hours	0.11	Roots	7172 Holt Run Dr - Cleaned Line
		06/03/21	0.0001	Wet Weather Release	Contained, did not reach water	Browns Creek SPS
000	09411001	06/11/21	0.1 hours	0.43	Other/not listed	1450 Lebanon Pk - Cleaned Vactor Truck Discharge
		06/11/21	0.0001	Wet Weather Overflow	Cumberland River	Browns Creek SPS
000	15014091	06/12/21	1 hours		Grit/Debris	6018 Mt View Rd - Cleaned Line
		06/12/21	0.00001	Dry Weather Release	Contained, did not reach water	Tillman SPS
000	08308007	06/25/21	2 hours		Grit/Debris	1045 Mitchell Rd - Cleaned Line
		06/25/21	0.00001	Dry Weather Release	Contained, did not reach water	Shelby Park SPS
000	17204020	06/28/21	2 hours		Grit/Debris	5897 Nolensville Pk - Cleaned Line
		06/28/21	0.00001	Dry Weather Overflow	Whittemore Branch	Browns Creek SPS
Monthly Totals: # of Events and Gallons				12 Month Rolling Totals: # of Events and Gallons		
Dry Weather Releases:	2	20	Wet Weather Releases:	1	100	Dry Weather Releases: 30 2,410 Wet Weather Releases: 23 1,991,925
Dry Weather Overflows:	1	10	Wet Weather Overflows:	1	100	Dry Weather Overflows: 27 6,300 Wet Weather Overflows: 243 1,242,960,860

Monthly Overflow Report

Date Range: June, 2021

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

Sanitary Sewer Overflows and Releases

000	05110061	06/28/21	4 hours		Other/not listed	101 Ellington PI - Contractor Repaired Line
		06/28/21	0.00001	Dry Weather Release	Contained, did not reach water	Loves Branch SPS
Monthly Totals: # of Events and Gallons				12 Month Rolling Totals: # of Events and Gallons		
Dry Weather Releases:	1	10	Wet Weather Releases:	0	0	Dry Weather Releases: 6 1,320 Wet Weather Releases: 1 10
Dry Weather Overflows:	0	0	Wet Weather Overflows:	0	0	Dry Weather Overflows: 3 25,010 Wet Weather Overflows: 28 71,838,000

Monthly Overflow Report

Date Range: June, 2021

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

Sanitary Sewer Overflows and Releases

000	09102079	06/10/21	3 hours	0.06	Grit/Debris	1604 56th Ave N - Cleaned Line	
		06/10/21	0.00005	Wet Weather Overflow	Richland Creek	West Park SPS	
114	Davidson Branch PS	06/02/21	6.33 hours	1.33	Rainfall	Infiltration/inflow. Station operating normally.	
		06/02/21	0.347	Wet Weather Overflow	Cumberland River	Davidson Branch SPS	
Monthly Totals: # of Events and Gallons				12 Month Rolling Totals: # of Events and Gallons			
Dry Weather Releases:	0	0	Wet Weather Releases:	0	0	Dry Weather Releases: 7 430 Wet Weather Releases: 19 2,887,230	
Dry Weather Overflows:	0	0	Wet Weather Overflows:	2	347,050	Dry Weather Overflows: 6 2,810 Wet Weather Overflows: 26 34,116,070	