

# Monthly Overflow Report

Date Range: June, 2023

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
<b>Sanitary Sewer Overflows and Releases</b>						
000	14805004	06/03/23	5 hours		Grease	3757 Faulkner Dr - Cleaned Line
		06/03/23	0.00005	Dry Weather Release	Contained, did not reach water	Browns Creek SPS
000	09303105	06/04/23	2 hours	0.10	Line Break	100 Woodland St - Cleaned Line
		06/04/23	0.00001	Wet Weather Release	Contained, did not reach water	Central WWTP
000	07112063	06/12/23	0.5 hours		Grit/Debris	911 Chickasaw Ave - Cleaned Line
		06/12/23	0.00001	Dry Weather Release	Contained, did not reach water	Central WWTP
000	09207092	06/13/23	24 hours		Grit/Debris	2302 Merry St - Cleaned Line
		06/13/23	0.00001	Dry Weather Release	Contained, did not reach water	Central WWTP
130	Browns Creek PS	06/12/23	38 hours		Force Main	1 Titans Way - Repaired FM
		06/14/23	0.0001	Dry Weather Release	Contained, did not reach water	Central WWTP
<b>Monthly Totals: # of Events and Gallons</b>				<b>12 Month Rolling Totals: # of Events and Gallons</b>		
<b>Dry Weather Releases:</b>	4	170	<b>Wet Weather Releases:</b>	1	10	<b>Dry Weather Releases:</b> 37 15,085 <b>Wet Weather Releases:</b> 27 4,950
<b>Dry Weather Overflows:</b>	0	0	<b>Wet Weather Overflows:</b>	0	0	<b>Dry Weather Overflows:</b> 11 1,029,330 <b>Wet Weather Overflows:</b> 45 9,723,560

# Monthly Overflow Report

Date Range: June, 2023

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

## Sanitary Sewer Overflows and Releases

No Overflows or Releases											
Monthly Totals: # of Events and Gallons						12 Month Rolling Totals: # of Events and Gallons					
Dry Weather Releases:	0	0	0	0	0	Dry Weather Releases:	2	110	Wet Weather Releases:	2	20
Dry Weather Overflows:	0	0	0	0	0	Dry Weather Overflows:	2	1,010	Wet Weather Overflows:	12	14,002,000

# Monthly Overflow Report

Date Range: June, 2023

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
<b>Sanitary Sewer Overflows and Releases</b>						
000	10404047	06/15/23	1.5 hours	0.04	Grit/Debris	1025 16th Ave S - Cleaned Line
		06/15/23	0.00001	Wet Weather Release	Contained, did not reach water	Central WWTP
000	11714084	06/20/23	0.5 hours	0.76	Line Break	3939 Hillsboro Cir, Repaired Line
		06/20/23	0.001	Wet Weather Overflow	Sugartree Creek	West Park SPS
000	10409078	06/29/23	2 hours	1.02	Line Break	3718 West End Ave - Repaired Line
		06/29/23	0.00001	Wet Weather Release	Contained, did not reach water	West Park SPS
<b>Monthly Totals: # of Events and Gallons</b>				<b>12 Month Rolling Totals: # of Events and Gallons</b>		
<b>Dry Weather Releases:</b>	0	0	<b>Wet Weather Releases:</b>	2	20	<b>Dry Weather Releases:</b> 7 250 <b>Wet Weather Releases:</b> 17 5,300
<b>Dry Weather Overflows:</b>	0	0	<b>Wet Weather Overflows:</b>	1	1,000	<b>Dry Weather Overflows:</b> 6 21,220 <b>Wet Weather Overflows:</b> 24 11,474,130