

Monthly Overflow Report

Date Range: March, 2021

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	08603013	03/01/21	26 hours	1.17	Rainfall	428 Old Lebanon Dirt Rd - Est 20 GPM
		03/02/21	0.03	Wet Weather Release	Contained, did not reach water	Dodson Chapel SPS
000	08602058	03/01/21	26 hours	1.17	Rainfall	428 Old Lebanon Dirt Rd - Est 10 GPM
		03/02/21	0.02	Wet Weather Release	Contained, did not reach water	Dodson Chapel SPS
000	11907144	03/01/21	26 hours	1.11	Rainfall	0 Old Glenrose Ave - Est 200 GPM
		03/02/21	0.3	Wet Weather Release	Contained, did not reach water	Browns Creek SPS
000	10503030	03/01/21	0.5 hours	0.29	Grit/Debris	1223 1st Ave S - Cleaned Line
		03/01/21	0.0001	Wet Weather Release	Contained, did not reach water	Browns Creek SPS
000	09310250	03/05/21	4 hours		Grit/Debris	700 Drexel St - Cleaned Line
		03/05/21	0.00001	Dry Weather Release	Contained, did not reach water	Central WWTP
000	09310249	03/05/21	4 hours		Grit/Debris	700 Drexel St - Cleaned Line
		03/05/21	0.00001	Dry Weather Release	Contained, did not reach water	Central WWTP
000	09310248	03/05/21	4 hours		Grit/Debris	700 Drexel St - Cleaned Line
		03/05/21	0.00001	Dry Weather Release	Contained, did not reach water	Central WWTP
000	13112013	03/05/21	67 hours		Grit/Debris	4417 Scenic Dr - Cleaned Line
		03/08/21	0.001	Dry Weather Overflow	Browns Creek	Browns Creek SPS
000	16311007	03/06/21	1 hours		Grease	5400 Bell Forge Ln E - Cleaned Line
		03/06/21	0.00001	Dry Weather Overflow	Collins Creek	Browns Creek SPS
000	07111100	03/12/21	1 hours	0.21	Grit/Debris	1553 Luton St - Cleaned Line
		03/12/21	0.000025	Wet Weather Release	Contained, did not reach water	Cowan Street SPS
000	08316012	03/18/21	3 hours	1.47	Grit/Debris	2706 Fortland Dr - Cleaned Line
		03/18/21	0.0001	Wet Weather Overflow	Cumberland River	Shelby Park SPS
000	07211063	03/18/21	14 hours	1.67	Grit/Debris	1432 Litton Ave - Cleaned Line
		03/19/21	0.0001	Wet Weather Overflow	Cooper Creek	Shelby Park SPS
000	13112013	03/18/21	4 hours	1.55	Rainfall	4417 Scenic Dr
		03/18/21	0.001	Wet Weather Overflow	Browns Creek	Browns Creek SPS
000	07208018	03/19/21	2 hours	1.67	Grit/Debris	1507 McGavock Pk - Cleaned Line
		03/19/21	0.00001	Wet Weather Release	Contained, did not reach water	Shelby Park SPS

Monthly Overflow Report

Date Range: March, 2021

000	09209161	03/20/21 03/21/21	24 hours 0.0001		Grit/Debris Phillips Branch	4068 Alameda St - Cleaned Line 28th Avenue SPS
000	10508028	03/20/21 03/20/21	4 hours 0.00001		Grit/Debris Browns Creek	333 Murfreesboro Pk - Cleaned Line Browns Creek SPS
000	09209003	03/20/21 03/21/21	21 hours 0.0001		Grit/Debris Phillips Branch	4068 Alameda St - Cleaned Line 28th Avenue SPS
000	13112013	03/26/21 03/26/21	8 hours 0.0001	1.28	Rainfall Wet Weather Overflow Browns Creek	4417 Scenic Dr Browns Creek SPS
000	13112013	03/27/21 04/01/21	120 hours 1.8	6.62	Rainfall Wet Weather Overflow Browns Creek	4417 Scenic Dr - Est 250 GPM Browns Creek SPS
000	11704059	03/27/21 03/27/21	2 hours 0.0001	3.87	Grit/Debris Wet Weather Overflow Browns Creek	1515 Dallas Ave - Cleaned Line Browns Creek SPS
000	11909113	03/27/21 03/29/21	48 hours 0.001	5.27	Rainfall Wet Weather Overflow Mill Creek	2803 Foster Ave Browns Creek SPS
000	12013044	03/27/21 03/29/21	48 hours 0.07	5.27	Rainfall Wet Weather Release Contained, did not reach water	910 Currey Rd - Est 25 GPM Browns Creek SPS
000	12013049	03/27/21 03/29/21	48 hours 0.07	5.27	Rainfall Wet Weather Release Contained, did not reach water	917 Currey Rd - Est 25 GPM Browns Creek SPS
000	11907049	03/27/21 03/29/21	48 hours 0.001	5.27	Rainfall Wet Weather Overflow Mill Creek	765 Old Glenrose Ave Browns Creek SPS
000	11907047	03/27/21 03/30/21	60 hours 0.001	5.34	Rainfall Wet Weather Overflow Mill Creek	0 Old Glenrose Ave Browns Creek SPS
000	07306035	03/28/21 03/29/21	14.75 hours 0.0005	5.47	Rainfall Wet Weather Release Contained, did not reach water	433 Opry Mills Dr Cabin Hill SPS
000	08602060	03/28/21 03/29/21	26 hours 0.3	6.50	Rainfall Wet Weather Release Contained, did not reach water	428 Old Lebanon Dirt Rd Dodson Chapel SPS
000	08603013	03/28/21 03/29/21	26 hours 0.3	6.50	Rainfall Wet Weather Release Contained, did not reach water	428 Old Lebanon Dirt Rd Dodson Chapel SPS
000	08603203	03/28/21 03/29/21	26 hours 0.3	6.50	Rainfall Wet Weather Release Contained, did not reach water	428 Old Lebanon Dirt Rd Dodson Chapel SPS
000	09805017	03/28/21 03/29/21	20 hours 0.00001	6.50	Rainfall Wet Weather Release Contained, did not reach water	6005 Port Jamaica Dodson Chapel SPS
000	11716037	03/28/21 03/29/21	30 hours 0.2	5.18	Rainfall Wet Weather Release Contained, did not reach water	3838 Granny White Pk - Est 125 GPM Browns Creek SPS

Monthly Overflow Report

Date Range: March, 2021

000	11716046	03/28/21 03/29/21	30 hours 0.2	5.18 Wet Weather Release	Rainfall Contained, did not reach water	3731 Granny White Pk - Est 125 GPM Browns Creek SPS
000	11716045	03/28/21 03/29/21	30 hours 0.2	5.71 Wet Weather Release	Rainfall Contained, did not reach water	3834 Granny White Pk Browns Creek SPS
000	08115087	03/30/21 03/30/21	4 hours 0.001	0.16 Wet Weather Overflow	Grit/Debris Cumberland River	1501 22nd Ave N - Cleaned Line 28th Avenue SPS
000	11712085	03/30/21 03/30/21	1 hours 0.00001	0.10 Wet Weather Overflow	Grit/Debris Browns Creek	1029 Noelton Ave - Cleaned Line Browns Creek SPS
000	11907049	03/31/21 03/31/21	21 hours 0.001	1.17 Wet Weather Overflow	Rainfall Mill Creek	765 Old Glenrose Ave Browns Creek SPS
000	11907147	03/31/21 03/31/21	21 hours 0.001	1.17 Wet Weather Overflow	Rainfall Mill Creek	0 Old Glenrose Ave Browns Creek SPS
102	Smith Springs PS	03/27/21 04/01/21	109.25 hours 4.869	8.80 Wet Weather Overflow	Rainfall Cumberland River	Infiltration/inflow. Station operating normally. Smith Springs SPS
103	McCrary Creek PS	03/27/21 03/29/21	56.67 hours 9.21	6.50 Wet Weather Overflow	Rainfall McCrary Creek	Infiltration/inflow. Station operating normally. McCrary Creek SPS
103	McCrary Creek PS	03/31/21 03/31/21	4.58 hours 0.098	1.28 Wet Weather Overflow	Rainfall McCrary Creek	Infiltration/inflow. Station operating normally. McCrary Creek SPS
122	Cloverbottom PS	03/27/21 03/30/21	60.68 hours 3	6.50 Wet Weather Overflow	Rainfall Stones River	Inflow/infiltration. Station operating normally. Clover Bottom SPS
130	Browns Creek PS	03/01/21 03/01/21	4.33 hours 0.087	1.11 Wet Weather Overflow	Rainfall Browns Creek	Infiltration/inflow. Station operating normally. Browns Creek SPS
130	Browns Creek PS	03/27/21 03/28/21	22.16 hours 15.469	5.27 Wet Weather Overflow	Rainfall Browns Creek	Infiltration/inflow. Station operating normally. Central WWTP
130	Browns Creek PS	03/31/21 03/31/21	2.17 hours 0.13	1.17 Wet Weather Overflow	Rainfall Browns Creek	Infiltration/inflow. Station operating normally. Browns Creek SPS
134	Riverside Drive PS	03/18/21 03/18/21	2.5 hours 0.05	1.61 Wet Weather Overflow	Rainfall Cumberland River	Inflow/infiltration. Station operating normally. Riverside Drive SPS
134	Riverside Drive PS	03/27/21 03/28/21	24.15 hours 0.4	5.46 Wet Weather Overflow	Rainfall Cumberland River	Inflow/infiltration. Station operating normally. Riverside Drive SPS
135	Clearlake PS	03/28/21 03/28/21	12.5 hours 0.1	7.16 Wet Weather Overflow	Rainfall Percy Priest Lake	Inflow/infiltration. Station operating normally. Clearlake Drive SPS
140	28th Avenue PS / Centennial	03/18/21 03/18/21	6.08 hours 3.964	1.61 Wet Weather Overflow	Rainfall Cumberland River	Infiltration/inflow. Station operating normally. 28th Avenue SPS

Monthly Overflow Report

Date Range: March, 2021

140	28th Avenue PS / Centennial	03/27/21 03/30/21	65.33 hours 3.436	6.48 Wet Weather Overflow	Rainfall Cumberland River	Infiltration/inflow. Station operating normally. 28th Avenue SPS
156	Bonnafair PS	03/27/21 03/29/21	31.5 hours 2	6.50 Wet Weather Overflow	Rainfall Cumberland River	Inflow/infiltration. Station operating normally. Bonnafair SPS
163	Tillman SPS	03/28/21 03/29/21	27 hours 1	7.16 Wet Weather Overflow	Rainfall Percy Priest Lake	Inflow/infiltration. Station operating normally. Tillman SPS
176	Dodson Chapel PS	03/01/21 03/02/21	28.17 hours 4.238	1.17 Wet Weather Overflow	Rainfall Stoners Creek	Infiltration/inflow. Station operating normally. Dodson Chapel SPS
176	Dodson Chapel PS	03/28/21 03/29/21	42.25 hours 2.408	6.50 Wet Weather Overflow	Rainfall Stoners Creek	Infiltration/inflow. Station operating normally. Dodson Chapel SPS
176	Dodson Chapel PS	03/31/21 03/31/21	7.17 hours 0.03	1.28 Wet Weather Overflow	Rainfall Stoners Creek	Infiltration/inflow. Station operating normally. Dodson Chapel SPS
179	Fairway Center PS	03/27/21 03/30/21	61.18 hours 1.25	5.01 Wet Weather Overflow	Rainfall Cumberland River	Inflow/infiltration. Station operating normally. Fairway Center SPS
181	South Shore SPS	03/27/21 03/28/21	31.9 hours 2	4.45 Wet Weather Overflow	Rainfall Percy Priest Lake	Inflow/infiltration. Station operating normally. South Shores SPS
181	South Shore SPS	03/31/21 03/31/21	10 hours 1	1.94 Wet Weather Overflow	Rainfall Percy Priest Lake	Inflow/infiltration. Station operating normally. South Shores SPS
182	Lakeshore SPS	03/28/21 03/28/21	6.4 hours 0.02	6.50 Wet Weather Overflow	Rainfall Percy Priest Lake	Inflow/infiltration. Station operating normally. Lakeshore SPS
183	Mill Creek PS	03/28/21 03/29/21	10.7 hours 0.1	6.50 Wet Weather Overflow	Rainfall Mill Creek	Inflow/infiltration. Station operating normally. Mill Creek SPS
184	Munn Rd PS	03/27/21 03/30/21	59 hours 0.5	6.50 Wet Weather Overflow	Rainfall Stones River	Inflow/infiltration. Station operating normally. Munn Road SPS
188	South Oak Hill PS	03/27/21 03/28/21	4.3 hours 0.3	6.21 Wet Weather Overflow	Rainfall Seven Mile Creek	Inflow/infiltration. Station operating normally. South Oak Hill SPS
189	Langford Farms PS	03/27/21 03/28/21	18.4 hours 0.2	4.90 Wet Weather Overflow	Rainfall Old Hickory Reservoir	Inflow/infiltration. Station operating normally. Langford Farms SPS
190	Towne Village PS	03/27/21 03/28/21	29.5 hours 0.2	7.16 Wet Weather Overflow	Rainfall Percy Priest Lake	Inflow/infiltration. Station operating normally. Towne Village SPS
222	149 Barker Road	03/18/21 03/18/21	21.42 hours 0.489	1.55 Wet Weather Overflow	Rainfall Cumberland River	Infiltration/inflow. Station operating normally. Barker Road SPS
222	149 Barker Road	03/25/21 04/03/21	186.75 hours 28.465	9.15 Wet Weather Overflow	Rainfall Cumberland River	Infiltration/inflow. Station operating normally. Barker Road SPS

Monthly Overflow Report

Date Range: March, 2021

226	Cowan St. Relief Bleeder	03/27/21	34 hours	4.59	Rainfall	Infiltration/inflow. Station at rated capacity.	
		03/29/21	2.338	Wet Weather Overflow	Cumberland River	Cowan Street SPS	
384	501 Bismark Dr.	03/18/21	12 hours	1.47	Rainfall	501 Bismark Dr - Est 500 GPM	
		03/18/21	0.36	Wet Weather Overflow	Mill Creek	Browns Creek SPS	
384	501 Bismark Dr.	03/27/21	144 hours	6.22	Rainfall	501 Bismark Dr - Est 500 GPM	
		04/02/21	4.3	Wet Weather Overflow	Mill Creek	Browns Creek SPS	
Monthly Totals: # of Events and Gallons				12 Month Rolling Totals: # of Events and Gallons			
Dry Weather Releases:	3	30	Wet Weather Releases:	16	1,990,645	Dry Weather Releases: 30 2,550	Wet Weather Releases: 24 1,992,925
Dry Weather Overflows:	5	1,220	Wet Weather Overflows:	44	93,818,410	Dry Weather Overflows: 28 8,200	Wet Weather Overflows: 2581,362,123,850

Monthly Overflow Report

Date Range: March, 2021

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	05315027	03/06/21	1.5 hours		Roots	688 Kings Way Dr - Cleaned Line
		03/06/21	0.00001	Dry Weather Release	Contained, did not reach water	Lakewood SPS
000	03406036	03/25/21	4 hours	1.21	Grit/Debris	1699 Gallatin Pk - Cleaned Line
		03/25/21	0.00001	Wet Weather Release	Contained, did not reach water	Dry Creek WWTP
000	03413034	03/28/21	26 hours	3.71	Rainfall	1450 Gallatin Pk - Est 100 GPM
		03/29/21	0.1	Wet Weather Overflow	Dry Creek	Dry Creek WWTP
106	Vandiver PS	03/27/21	19.5 hours	4.64	Rainfall	Infiltration/inflow. Station operating normally.
		03/28/21	0.942	Wet Weather Overflow	Cumberland River	Vandiver SPS
108	River Retreat	03/27/21	69.15 hours	4.82	Rainfall	Inflow/infiltration. Station operating normally.
		03/30/21	4	Wet Weather Overflow	Cumberland River	River Retreat SPS
109	Dry Creek PS	03/28/21	0.33 hours	5.66	Rainfall	Infiltration/inflow. Station operating normally.
		04/01/21	0.046	Wet Weather Overflow	Cumberland River	Dry Creek SPS
110	Loves Branch PS	03/27/21	13.58 hours	4.82	Rainfall	Infiltration/inflow. Station operating normally.
		03/28/21	1.523	Wet Weather Overflow	Cumberland River	Loves Branch SPS
112	Gibson Creek PS	03/27/21	11.09 hours	4.82	Rainfall	Infiltration/inflow. Station operating normally.
		03/28/21	0.79	Wet Weather Overflow	Gibson Creek	Gibson Creek SPS
112	Gibson Creek PS	03/30/21	8.5 hours	0.84	Rainfall	Infiltration/inflow. Station operating normally.
		03/30/21	0.22	Wet Weather Overflow	Gibson Creek	Gibson Creek SPS
123	Lakewood PS	03/27/21	42.15 hours	4.64	Rainfall	Inflow/infiltration. Station operating normally.
		03/29/21	0.7	Wet Weather Overflow	Cumberland River	Lakewood SPS
132	Berwick Trail PS / Center St	03/28/21	48.68 hours	4.82	Rainfall	Inflow/infiltration. Station operating normally.
		03/30/21	0.3	Wet Weather Overflow	Cumberland River	Berwick Trail SPS
150	Hidden Acres PS	03/27/21	72.15 hours	4.88	Rainfall	Inflow/infiltration. Station operating normally.
		03/30/21	1	Wet Weather Overflow	Cumberland River	Hidden Acres SPS
185	Old Hickory PS	03/28/21	40.15 hours	4.64	Rainfall	Inflow/infiltration. Station operating normally.
		03/30/21	2.5	Wet Weather Overflow	Cumberland River	Old Hickory SPS
193	Gail Drive PS	03/27/21	46.4 hours	4.59	Rainfall	Inflow/infiltration. Station operating normally.
		03/29/21	1	Wet Weather Overflow	Unnamed water body	Gail Drive SPS

Monthly Overflow Report

Date Range: March, 2021

<i>Monthly Totals: # of Events and Gallons</i>				<i>12 Month Rolling Totals: # of Events and Gallons</i>							
<i>Dry Weather Releases:</i>	1	10	<i>Wet Weather Releases:</i>	1	10	<i>Dry Weather Releases:</i>	5	1,310	<i>Wet Weather Releases:</i>	1	10
<i>Dry Weather Overflows:</i>	0	0	<i>Wet Weather Overflows:</i>	12	13,121,000	<i>Dry Weather Overflows:</i>	6	235,020	<i>Wet Weather Overflows:</i>	33	73,392,000

Monthly Overflow Report

Date Range: March, 2021

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date End Date	Duration (hrs) Volume (mg)	Rainfall Overflow Type	Overflow Cause Receiving Stream	Remarks Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	13103010	03/01/21 03/02/21	21 hours 0.025	1.16 Wet Weather Release	Rainfall Contained, did not reach water	2000 Galbraith Dr - Est 20 GPM West Park SPS
000	09105017	03/05/21 03/05/21	3 hours 0.001		Grit/Debris Richland Creek	634 Nashua Ln - Cleaned Line West Park SPS
000	11709060	03/19/21 03/19/21	2 hours 0.00001	1.87 Wet Weather Overflow	Grit/Debris Sugartree Creek	3715 Sugar Tree Pl - Cleaned Line West Park SPS
000	10303049	03/26/21 03/26/21	5 hours 0.0001		Grit/Debris Contained, did not reach water	5522 Bonair Cir - Cleaned Line West Park SPS
000	13103010	03/27/21 03/29/21	53 hours 0.16	5.27 Wet Weather Release	Rainfall Contained, did not reach water	2000 Galbraith Dr - Est 50 GPM West Park SPS
000	06001013	03/27/21 03/29/21	34 hours	4.75 Wet Weather Release	Rainfall Contained, did not reach water	3258 Brick Church Pk Whites Creek SPS
000	05911028	03/27/21 03/29/21	48 hours 0.7	4.75 Wet Weather Release	Rainfall Contained, did not reach water	709 Rowan Dr Whites Creek SPS
000	05911027	03/27/21 03/29/21	36 hours 0.5	4.75 Wet Weather Release	Rainfall Contained, did not reach water	701 Rowan Dr - Est 250 GPM Whites Creek SPS
000	05911036	03/28/21 03/29/21	39 hours 0.4	5.46 Wet Weather Release	Rainfall Contained, did not reach water	3818 Cravath Dr Whites Creek SPS
000	11705041	03/28/21 03/29/21	28 hours 0.2	5.18 Wet Weather Release	Rainfall Contained, did not reach water	712 Bowling Ave - Est 125 GPM West Park SPS
000	05915017	03/28/21 03/29/21	39 hours 0.4	5.46 Wet Weather Release	Rainfall Contained, did not reach water	3812 Cravath Dr Whites Creek SPS
000	05910048	03/28/21 03/29/21	39 hours 0.1	5.46 Wet Weather Release	Rainfall Contained, did not reach water	748 Rowan Dr Whites Creek SPS
000	05911029	03/28/21 03/29/21	40 hours 0.1	5.46 Wet Weather Release	Rainfall Contained, did not reach water	717 Rowan Dr - Est 50 GPM Whites Creek SPS
000	11612076	03/28/21 03/29/21	30 hours 0.2	5.18 Wet Weather Release	Rainfall Contained, did not reach water	3600 Abbott Martin Rd - Est 100 GPM West Park SPS

Monthly Overflow Report

Date Range: March, 2021

000	14409005	03/31/21 04/01/21	13 hours 0.00001	1.48 Wet Weather Overflow	Grit/Debris Richland Creek	4362 Chickering Ln - Cleaned Line West Park SPS
107	West Park PS	03/27/21 03/31/21	50.08 hours 11.516	5.76 Wet Weather Overflow	Rainfall Richland Creek	Infiltration/inflow. Station operating normally. West Park SPS
114	Davidson Branch PS	03/17/21 03/18/21	26.33 hours 1.831	1.71 Wet Weather Overflow	Rainfall Cumberland River	Infiltration/inflow. Station operating normally. Davidson Branch SPS
114	Davidson Branch PS	03/25/21 03/26/21	9.08 hours 0.481	1.17 Wet Weather Overflow	Rainfall Cumberland River	Infiltration/inflow. Station operating normally. Davidson Branch SPS
114	Davidson Branch PS	03/27/21 03/31/21	46.68 hours 2.525	5.76 Wet Weather Overflow	Rainfall Cumberland River	Infiltration/inflow. Station operating normally. Davidson Branch SPS
126	Cleeces Ferry PS	03/28/21 03/28/21	14.5 hours 0.3	4.80 Wet Weather Overflow	Rainfall Cumberland River	Inflow/infiltration. Station operating normally. Cleeces Ferry SPS
136	River Drive PS	03/27/21 03/28/21	7 hours 0.174	5.46 Wet Weather Overflow	Rainfall Cumberland River	Inflow/infiltration. Station operating normally. River Drive SPS
138	Sunliner PS	03/27/21 03/28/21	7.3 hours 0.3	4.80 Wet Weather Overflow	Rainfall Cumberland River	Inflow/infiltration. Station operating normally. Sunliner Drive SPS
145	Joelton PS	03/18/21 03/18/21	5 hours 0.02	1.60 Wet Weather Overflow	Rainfall Tributary to Long Creek	Inflow/infiltration. Station operating normally. Joelton SPS
145	Joelton PS	03/27/21 03/28/21	29 hours 0.1	2.98 Wet Weather Overflow	Rainfall Tributary to Long Creek	Inflow/infiltration. Station operating normally. Joelton SPS
217	516 Basswood Ave.	03/27/21 03/31/21	66.75 hours 8.882	5.76 Wet Weather Overflow	Rainfall Cumberland River	516 Basswood Ave West Park SPS

<i>Monthly Totals: # of Events and Gallons</i>				<i>12 Month Rolling Totals: # of Events and Gallons</i>						
Dry Weather Releases:	1	100	Wet Weather Releases:	11	2,785,000	Dry Weather Releases:	8 620	Wet Weather Releases:	19	2,856,230
Dry Weather Overflows:	1	1,000	Wet Weather Overflows:	12	26,129,020	Dry Weather Overflows:	7 2,910	Wet Weather Overflows:	27	34,039,220