

Monthly Overflow Report

Date Range: March, 2022

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	13314009	03/02/22	2 hours		Grit/Debris	411 Elysian Fields Rd - Cleaned Line
		03/02/22	0.00001	Dry Weather Release	Contained, did not reach water	Browns Creek SPS
000	13413029	03/02/22	1 hours		Grit/Debris	200 Paragon Mills Rd - Cleaned Line
		03/02/22	0.00001	Dry Weather Release	Contained, did not reach water	Browns Creek SPS
000	17201060	03/03/22	17 hours		Grit/Debris	204 Sterling Oaks PI - Cleaned Line
		03/04/22	0.0001	Dry Weather Release	Contained, did not reach water	Browns Creek SPS
000	16002030	03/08/22	2 hours	0.43	Force Main	5202 Franklin Pk
		03/09/22	0.0001	Wet Weather Overflow	Seven Mile Creek	South Oak Hill SPS
000	17201060	03/08/22	4 hours	0.43	Grit/Debris	204 Sterling Oaks PI - Cleaned Line
		03/08/22	0.0001	Wet Weather Release	Contained, did not reach water	Browns Creek SPS
000	14703008	03/09/22	4 hours	0.27	Grit/Debris	4095 Nolensville Pk - Cleaned Line
		03/09/22	0.00001	Wet Weather Overflow	Seven Mile Creek	Browns Creek SPS
000	09306301	03/10/22	1 hours		Grit/Debris	121 4th Ave S - Cleaned Line
		03/10/22	0.00001	Dry Weather Release	Contained, did not reach water	Central WWTP
000	09206096	03/25/22	2 hours		Grit/Debris	2516 Booker St - Cleaned Line
		03/25/22	0.00001	Dry Weather Release	Contained, did not reach water	28th Avenue SPS
000	14703008	03/26/22	7 hours		Grit/Debris	4095B Nolensville Pk - Cleaned Line
		03/27/22	0.00001	Dry Weather Overflow	Seven Mile Creek	Browns Creek SPS
000	05415044	03/27/22	46 hours		Grit/Debris	541 Robards Cir - Cleaned Line
		03/29/22	0.0001	Dry Weather Release	Contained, did not reach water	Brandywine Pointe SPS
000	07101037	03/30/22	5 hours	0.89	Grit/Debris	2223 Whites Creek Pk - Cleaned Line
		03/30/22	0.0001	Wet Weather Release	Contained, did not reach water	Riverside Drive SPS
000	16310055	03/30/22	2 hours	1.01	Grease	5316 Mt View Rd - Cleaned Line
		03/30/22	0.0001	Wet Weather Overflow	Collins Creek	Browns Creek SPS
384	501 Bismark Dr.	03/23/22	17 hours	1.67	Rainfall	501 Bismark Dr
		03/23/22	0.5	Wet Weather Overflow	Mill Creek	Browns Creek SPS

Monthly Overflow Report

Date Range: March, 2022

<i>Monthly Totals: # of Events and Gallons</i>					<i>12 Month Rolling Totals: # of Events and Gallons</i>						
<i>Dry Weather Releases:</i>	6	240	<i>Wet Weather Releases:</i>	2	200	<i>Dry Weather Releases:</i>	24	1,990	<i>Wet Weather Releases:</i>	31	610,930
<i>Dry Weather Overflows:</i>	1	10	<i>Wet Weather Overflows:</i>	4	500,210	<i>Dry Weather Overflows:</i>	20	1,916,120	<i>Wet Weather Overflows:</i>	260	1,133,126,770

Monthly Overflow Report

Date Range: March, 2022

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

Sanitary Sewer Overflows and Releases

000	04309047	03/15/22	1 hours		Grit/Debris	408 Delaware Ave - Cleaned Line	
		03/15/22	0.0001	Dry Weather Overflow	Gibson Creek	Gibson Creek SPS	
Monthly Totals: # of Events and Gallons					12 Month Rolling Totals: # of Events and Gallons		
Dry Weather Releases:	0	0	Wet Weather Releases:	0	0	Dry Weather Releases: 3 210 Wet Weather Releases: 2 110	
Dry Weather Overflows:	1	100	Wet Weather Overflows:	0	0	Dry Weather Overflows: 2 1,100 Wet Weather Overflows: 42 16,606,000	

Monthly Overflow Report

Date Range: March, 2022

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

Sanitary Sewer Overflows and Releases

000	03116014	03/15/22	10 hours	0.11	Grit/Debris	575 Hickory Hills Blvd - Cleaned Line
		03/16/22	0.00001	Wet Weather Release	Contained, did not reach water	Whites Creek SPS
114	Davidson Branch PS	03/22/22	6.17 hours	1.39	Rainfall	Infiltration/inflow. Station operating normally.
		03/23/22	0.168	Wet Weather Overflow	Cumberland River	Davidson Branch SPS
114	Davidson Branch PS	03/30/22	0.75 hours	1.14	Rainfall	Infiltration/inflow. Station operating normally.
		03/31/22	0.038	Wet Weather Overflow	Cumberland River	Davidson Branch SPS
145	Joelton PS	03/23/22	2.5 hours	1.38	Rainfall	Infiltration/inflow. Station operating normally
		03/23/22	0.01	Wet Weather Overflow	Tributary to Long Creek	Joelton SPS

Monthly Totals: # of Events and Gallons					12 Month Rolling Totals: # of Events and Gallons						
Dry Weather Releases:	0	0	Wet Weather Releases:	1	10	Dry Weather Releases:	4	220	Wet Weather Releases:	19	1,032,600
Dry Weather Overflows:	0	0	Wet Weather Overflows:	3	216,000	Dry Weather Overflows:	6	110,360	Wet Weather Overflows:	54	21,168,250