

Monthly Overflow Report

Date Range: March, 2023

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	13112013	03/02/23	21 hours	1.10	Rainfall	4417 Scenic Dr
		03/03/23	0.001	Wet Weather Overflow	Browns Creek	Browns Creek SPS
000	16316045	03/04/23	2 hours		Grit/Debris	2400 Danilynn Cir - Cleaned Line
		03/04/23	0.00001	Dry Weather Overflow	Collins Creek	Browns Creek SPS
000	17506029	03/06/23	1.5 hours		Grease	1156 Shallowbrook Trl - Cleaned Line
		03/06/23	0.0001	Dry Weather Release	Contained, did not reach water	Preserves at Old Hickory SPS
000	08209025	03/10/23	3 hours		Grit/Debris	1216 3rd Ave N - Cleaned Line
		03/10/23	0.00001	Dry Weather Release	Contained, did not reach water	Central WWTP
000	17506029	03/11/23	2 hours	0.35	Grease	1156 Shallowbrook Trl - Cleaned Line
		03/11/23	0.001	Wet Weather Release	Contained, did not reach water	Preserves at Old Hickory SPS
000	08208091	03/18/23	1.5 hours		Grit/Debris	803 N 6th St - Cleaned Line
		03/18/23	0.00001	Dry Weather Release	Contained, did not reach water	Central WWTP
000	17401012	03/26/23	3 hours		Grit/Debris	2174 Rivendell Trc - Cleaned Line
		03/26/23	0.0001	Dry Weather Release	Contained, did not reach water	Browns Creek SPS
000	06013052	03/29/23	3 hours		Grit/Debris	423 Woodfolk Ave - Cleaned Line
		03/29/23	0.00001	Dry Weather Overflow	Pages Branch	Cowan Street SPS
000	08103031	03/30/23	19 hours	0.24	Line Break	2145 18th Ave N - Repaired Line
		03/31/23	0.00001	Wet Weather Release	Contained, did not reach water	Fairway Center SPS
000	16206019	03/31/23	0.5 hours	0.12	Grit/Debris	117 Valley Green Dr - Cleaned Line
		03/31/23	0.00001	Wet Weather Release	Contained, did not reach water	Browns Creek SPS
195	Beacon Hill PS	03/03/23	6.4 hours	1.07	Power Related	Extended power loss due to wind storm.
		03/04/23	0.02	Wet Weather Overflow	Cumberland River	Beacon Hill SPS
226	Cowan St. Relief Bleeder	03/03/23	36.09 hours	0.70	Power Related	Extended power loss due to wind storm.
		03/05/23	0.824	Wet Weather Overflow	Cumberland River	Cowan Street SPS
Monthly Totals: # of Events and Gallons					12 Month Rolling Totals: # of Events and Gallons	
Dry Weather Releases:	4	220	Wet Weather Releases:	3	1,020	Dry Weather Releases: 37 15,005 Wet Weather Releases: 32 15,030
Dry Weather Overflows:	2	20	Wet Weather Overflows:	3	845,000	Dry Weather Overflows: 15 1,030,450 Wet Weather Overflows: 47 13,874,650

Monthly Overflow Report

Date Range: March, 2023

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

Sanitary Sewer Overflows and Releases

000	03403011	03/22/23	1 hours	0.48	Grit/Debris	208 Twinhill Dr - Cleaned Line	
		03/22/23	0.00001	Wet Weather Release	Contained, did not reach water	Dry Creek SPS	
106	Vandiver PS	03/03/23	0.92 hours	0.73	Power Related	Extended power loss due to wind storm.	
		03/03/23	0.029	Wet Weather Overflow	Cumberland River	Vandiver SPS	
Monthly Totals: # of Events and Gallons				12 Month Rolling Totals: # of Events and Gallons			
Dry Weather Releases:	0	0	Wet Weather Releases:	1	10	Dry Weather Releases: 3 610 Wet Weather Releases: 2 20	
Dry Weather Overflows:	0	0	Wet Weather Overflows:	1	29,000	Dry Weather Overflows: 2 1,010 Wet Weather Overflows: 16 14,024,000	

Monthly Overflow Report

Date Range: March, 2023

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	09102078	03/04/23	0.5 hours		Grit/Debris	5511 Centennial Blvd - Cleaned Line
		03/04/23	0.00001	Dry Weather Overflow	Cumberland River	West Park SPS
114	Davidson Branch PS	03/03/23	17.5 hours	0.71	Rainfall	Infiltration/inflow. Station operating normally.
		03/04/23	0.633	Wet Weather Overflow	Cumberland River	Davidson Branch SPS
114	Davidson Branch PS	03/25/23	24.25 hours	1.05	Rainfall	Infiltration/inflow. Station operating normally.
		03/26/23	1.169	Wet Weather Overflow	Cumberland River	Davidson Branch SPS
Monthly Totals: # of Events and Gallons				12 Month Rolling Totals: # of Events and Gallons		
Dry Weather Releases:	0	0	Wet Weather Releases:	0	0	Dry Weather Releases: 4 40 Wet Weather Releases: 16 305,190
Dry Weather Overflows:	1	10	Wet Weather Overflows:	2	1,802,000	Dry Weather Overflows: 6 1,230 Wet Weather Overflows: 31 12,706,130