

Monthly Overflow Report

Date Range: November, 2022

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date End Date	Duration (hrs) Volume (mg)	Rainfall Overflow Type	Overflow Cause Receiving Stream	Remarks Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	14911019	11/01/22 11/01/22	1 hours 0.0001		Grit/Debris Dry Weather Release	5160 Rice Rd - Cleaned Line Browns Creek SPS
000	07601053	11/04/22 11/04/22	1 hours 0.00001	0.01	Roots Wet Weather Release	829 Oak Leaf Dr - Cleaned Line Dodson Chapel SPS
000	09203091	11/08/22 11/08/22	1 hours 0.0001		Grit/Debris Dry Weather Release	1813 Hermosa St - Cleaned Line Central WWTP
000	09206042	11/11/22 11/11/22	1 hours 0.0001	2.75	Grit/Debris Wet Weather Release	904 26th Ave N - Cleaned Line 28th Avenue SPS
000	09206029	11/11/22 11/11/22	1 hours 0.0001	2.75	Grit/Debris Wet Weather Overflow	904 26th Ave N - Cleaned Line 28th Avenue SPS
000	08603023	11/11/22 11/11/22	1 hours 0.0001	1.83	Grit/Debris Wet Weather Release	0 Old Lebanon Dirt Rd - Cleaned Line Dodson Chapel SPS
000	10709099	11/18/22 11/18/22	1 hours 0.00001		Grit/Debris Dry Weather Release	900 Glastonbury Rd - Cleaned Line Browns Creek SPS
000	09611008	11/19/22 11/19/22	2 hours 0.00001		Grit/Debris Dry Weather Release	338 Hickory Pl - Cleaned Line Central WWTP
000	14913024	11/21/22 11/21/22	4 hours 0.001		Grease Dry Weather Overflow	4701 Bowfield Dr - Cleaned Line Browns Creek SPS
000	13112057	11/25/22 11/25/22	5 hours 0.00001	0.02	Line Break Wet Weather Release	4603 Lealand Ln - Cleaned Line Browns Creek SPS
000	11907144	11/30/22 11/30/22	4.42 hours 0.05	1.26	Rainfall Wet Weather Overflow	0 Old Glenrose Ave Browns Creek SPS
102	Smith Springs PS	11/11/22 11/11/22	8.42 hours 0.162	1.75	Rainfall Wet Weather Overflow	Infiltration/inflow. Station operating normally. Smith Springs SPS
102	Smith Springs PS	11/30/22 11/30/22	7.75 hours 0.268	1.92	Mechanical Wet Weather Overflow	EQ drain valve failed open Smith Springs SPS
134	Riverside Drive PS	11/11/22 11/11/22	5.2 hours 0.1	3.72	Rainfall Wet Weather Overflow	Infiltration/inflow. Station operating normally. Riverside Drive SPS

Monthly Overflow Report

Date Range: November, 2022

187	Peppertree PS	11/29/22	8.5 hours	2.55	Rainfall	Infiltration/inflow. Station operating normally.	
		11/30/22	0.1	Wet Weather Overflow	Percy Priest Lake	Peppertree SPS	
384	501 Bismark Dr.	11/30/22	11.17 hours	1.27	Rainfall	501 Bismark Ave	
		11/30/22	0.3	Wet Weather Overflow	Mill Creek	Browns Creek SPS	
Monthly Totals: # of Events and Gallons				12 Month Rolling Totals: # of Events and Gallons			
Dry Weather Releases:		4	220	Wet Weather Releases:		4	220
Dry Weather Overflows:		1	1,000	Wet Weather Overflows:		7	980,100
Dry Weather Releases:		37	13,190	Wet Weather Releases:		45	623,350
Dry Weather Overflows:		17	1,003,130	Wet Weather Overflows:		235	911,300,840

Monthly Overflow Report

Date Range: November, 2022

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

Sanitary Sewer Overflows and Releases

No Overflows or Releases											
Monthly Totals: # of Events and Gallons					12 Month Rolling Totals: # of Events and Gallons						
Dry Weather Releases:	0	0	Wet Weather Releases:	0	0	Dry Weather Releases:	2	510	Wet Weather Releases:	1	10
Dry Weather Overflows:	0	0	Wet Weather Overflows:	0	0	Dry Weather Overflows:	2	1,100	Wet Weather Overflows:	32	9,958,000

Monthly Overflow Report

Date Range: November, 2022

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
Sanitary Sewer Overflows and Releases						
000	05911028	11/11/22	2 hours	3.72	Rainfall	709 Rowan Dr
		11/11/22	0.00001	Wet Weather Release	Contained, did not reach water	Whites Creek SPS
000	05809006	11/28/22	3 hours		Grease	4416 Eatons Creek Rd - Cleaned Line
		11/28/22	0.0001	Dry Weather Overflow	Drakes Branch	Whites Creek SPS
114	Davidson Branch PS	11/30/22	7.08 hours	1.43	Rainfall	Infiltration/inflow. Station operating normally.
		11/30/22	0.418	Wet Weather Overflow	Cumberland River	Davidson Branch SPS
136	River Drive PS	11/11/22	1.67 hours	3.72	Rainfall	Infiltration/inflow. Station at rated capacity.
		11/11/22	0.005	Wet Weather Overflow	Cumberland River	River Drive SPS
217	516 Basswood Ave.	11/30/22	0.92 hours	1.43	Rainfall	516 Basswood Dr
		11/30/22	0.002	Wet Weather Overflow	Cumberland River	West Park SPS
Monthly Totals: # of Events and Gallons				12 Month Rolling Totals: # of Events and Gallons		
Dry Weather Releases:	0	0	Wet Weather Releases:	1	10	Dry Weather Releases: 4 130 Wet Weather Releases: 18 1,302,590
Dry Weather Overflows:	1	100	Wet Weather Overflows:	3	425,000	Dry Weather Overflows: 7 111,230 Wet Weather Overflows: 47 15,905,100