

# Monthly Overflow Report

Date Range: October, 2021

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

## Sanitary Sewer Overflows and Releases

000	09214021	10/13/21	0.5 hours		Other/not listed	350 28th Ave N - Repaired Bypass Pumps	
		10/13/21	0.0001	Dry Weather Release	Contained, did not reach water	Central WWTP	
000	13306103	10/18/21	69 hours		Grease	411 Allied Dr - Cleaned Line	
		10/21/21	0.001	Dry Weather Overflow	Seven Mile Creek	Browns Creek SPS	
000	09214021	10/20/21	0.5 hours		Other/not listed	350 28th Ave N - Repaired Bypass Pumps	
		10/20/21	0.0001	Dry Weather Release	Contained, did not reach water	Central WWTP	
000	13104116	10/25/21	24 hours	1.32	Grit/Debris	1505 Shackelford Rd - Cleaned Line	
		10/26/21	0.00001	Wet Weather Release	Contained, did not reach water	Browns Creek SPS	
000	08310014	10/28/21	4 hours	0.35	Grit/Debris	2009 Sevier St - Cleaned Line	
		10/28/21	0.001	Wet Weather Overflow	Cumberland River	Shelby Park SPS	
<b>Monthly Totals: # of Events and Gallons</b>					<b>12 Month Rolling Totals: # of Events and Gallons</b>		
<b>Dry Weather Releases:</b>	2	200	<b>Wet Weather Releases:</b>	1	10	<b>Dry Weather Releases:</b> 29 2,220	<b>Wet Weather Releases:</b> 26 1,991,055
<b>Dry Weather Overflows:</b>	1	1,000	<b>Wet Weather Overflows:</b>	1	1,000	<b>Dry Weather Overflows:</b> 25 1,920,940	<b>Wet Weather Overflows:</b> 239 1,495,330,970

# Monthly Overflow Report

Date Range: October, 2021

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

## Sanitary Sewer Overflows and Releases

000	03310061	10/26/21	26 hours		Grit/Debris	1297 Dickerson Pk - Cleaned Line
		10/27/21	0.001	Dry Weather Overflow	Dry Creek	Dry Creek WWTP

Monthly Totals: # of Events and Gallons					12 Month Rolling Totals: # of Events and Gallons						
<b>Dry Weather Releases:</b>	0	0	<b>Wet Weather Releases:</b>	0	0	<b>Dry Weather Releases:</b>	6	1,320	<b>Wet Weather Releases:</b>	2	110
<b>Dry Weather Overflows:</b>	1	1,000	<b>Wet Weather Overflows:</b>	0	0	<b>Dry Weather Overflows:</b>	2	4,000	<b>Wet Weather Overflows:</b>	38	74,186,000

# Monthly Overflow Report

Date Range: October, 2021

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
<b>Sanitary Sewer Overflows and Releases</b>						
000	11713043	10/26/21	4 hours		Grit/Debris	1210 Grandview Dr - Cleaned Line
		10/26/21	0.0001	Dry Weather Release	Contained, did not reach water	Browns Creek SPS
114	Davidson Branch PS	10/03/21	3.67 hours	1.16	Rainfall	Infiltration/inflow. Station operating normally.
		10/03/21	0.105	Wet Weather Overflow	Cumberland River	Davidson Branch SPS
114	Davidson Branch PS	10/25/21	4.75 hours	1.45	Rainfall	Infiltration/inflow. Station operating normally.
		10/25/21	0.166	Wet Weather Overflow	Cumberland River	Davidson Branch SPS
<b>Monthly Totals: # of Events and Gallons</b>				<b>12 Month Rolling Totals: # of Events and Gallons</b>		
<b>Dry Weather Releases:</b>	1	100	<b>Wet Weather Releases:</b>	0	0	<b>Dry Weather Releases:</b> 6 330 <b>Wet Weather Releases:</b> 18 2,887,040
<b>Dry Weather Overflows:</b>	0	0	<b>Wet Weather Overflows:</b>	2	271,000	<b>Dry Weather Overflows:</b> 9 2,970 <b>Wet Weather Overflows:</b> 40 40,699,170