

Monthly Overflow Report

Date Range: September, 2020

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	17210101	09/07/20	09/07/20	5 hours	0.0001		Grit/Debris	520 Ceret Aly - Cleaned Line
000	15003011	09/10/20	09/10/20	2 hours	0.00001		Grit/Debris	3401 Country Hill Rd - Cleaned Line
000	13413023	09/11/20	09/12/20	3 hours	0.0001		Grease	204 Largo Dr - Cleaned Line
000	15007050	09/13/20	09/13/20	10 hours	0.0001	4.48	Rainfall	3192 Country Meadow Rd
000	14907016	09/17/20	09/17/20	2 hours	0.0001		Grit/Debris	2240 Edge O Lake Dr - Cleaned Line
000	09214008	09/24/20	10/02/20	192 hours	0.001	0.10	Line Break	2545 Park Plaza - Bypass Pumping, Repair In Progress
000	07211009	09/26/20	09/26/20	4 hours	0.00001		Line Break	121 Piedmont Ave - Repaired Line
102	Smith Springs PS	09/13/20	09/14/20	25.25 hours	2.3	4.48	Rainfall	Infiltration/inflow. EQ full.
103	McCrary Creek PS	09/13/20	09/13/20	10 hours	2.074	3.40	Rainfall	Infiltration/inflow. Station operating normally.
125	Hopedale PS	09/13/20	09/13/20	2.1 hours	0.01	2.71	Rainfall	Infiltration/inflow. Station operating normally.
131	Hurricane Creek PS	09/13/20	09/14/20	30 hours	1.8	6.29	Rainfall	Infiltration/inflow. Station operating normally.
135	Clearlake PS	09/13/20	09/13/20	11.5 hours	0.07	4.51	Rainfall	Infiltration/inflow. Station operating normally.
153	Countryside Drive SPS	09/13/20	09/13/20	2 hours	0.02	6.11	Rainfall	Infiltration/inflow. Station operating normally.
157	Old Hickory Hills PS	09/13/20	09/13/20	7 hours	0.05	6.11	Rainfall	Infiltration/inflow. Station operating normally.
161	Longhunter Chase SPS	09/13/20	09/13/20	0.75 hours	0.03	6.29	Rainfall	Infiltration/inflow. Station operating normally.
163	Tillman SPS	09/13/20	09/13/20	19 hours	0.7	6.29	Rainfall	Infiltration/inflow. Station operating normally.
175	Baronswood Dr	09/01/20	09/01/20	0.67 hours	0.001	2.16	Rainfall	Infiltration/inflow. Station operating normally.
175	Baronswood Dr	09/13/20	09/13/20	7 hours	0.001	6.11	Rainfall	Infiltration/inflow. Station operating normally.
181	South Shore SPS	09/13/20	09/13/20	0.5 hours	0.03	6.29	Rainfall	Infiltration/inflow. Station operating normally.
186	Mt. View SPS	09/13/20	09/13/20	6 hours	0.07	6.29	Rainfall	Infiltration/inflow. Station operating normally.
187	Peppertree PS	09/13/20	09/13/20	15.5 hours	0.2	6.29	Rainfall	Infiltration/inflow. Station operating normally.
189	Langford Farms PS	09/13/20	09/13/20	4.7 hours	0.05	3.76	Rainfall	Infiltration/inflow. Station operating normally.
190	Towne Village PS	09/13/20	09/13/20	11 hours	0.05	4.51	Rainfall	Infiltration/inflow. Station operating normally.
222	149 Barker Road	09/13/20	09/13/20	12.42 hours	1.047	3.40	Rainfall	Infiltration/inflow. Station operating normally.

Monthly Overflow Report

Date Range: September, 2020

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05206008	09/15/20	09/15/20	0.5 hours	0.0001		Roots	748 Howse Ave - Cleaned Line
000	04414016	09/22/20	09/22/20	1 hours	0.0001		Grease	1205 Robinson Rd - Cleaned Line
106	Vandiver PS	09/13/20	09/13/20	8.5 hours	0.462	2.60	Rainfall	Infiltration/inflow. Station operating normally.
109	Dry Creek PS	09/13/20	09/13/20	7.67 hours	2.81	2.36	Rainfall	Infiltration/inflow. Station operating normally.
110	Loves Branch PS	09/13/20	09/13/20	4.25 hours	0.106	2.36	Rainfall	Infiltration/inflow. Station operating normally.
110	Loves Branch PS	09/29/20	09/29/20	0.83 hours	0.022	0.00	Force Main	Force main shutdown.
112	Gibson Creek PS	09/13/20	09/13/20	13.5 hours	1.339	2.36	Rainfall	Infiltration/inflow. Station operating normally.
123	Lakewood PS	09/13/20	09/13/20	2.7 hours	0.05	5.40	Rainfall	Infiltration/inflow. Station operating normally.
150	Hidden Acres PS	09/13/20	09/13/20	6.3 hours	0.5	2.77	Rainfall	Infiltration/inflow. Station operating normally.

Monthly Overflow Report

Date Range: September, 2020

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	07009085	09/03/20	09/04/20	18 hours	0.0001	0.03	Force Main	2400 Buena Vista Pk - Repaired FM
114	Davidson Branch PS	09/12/20	09/12/20	3.17 hours	0.181	0.73	Rainfall	Infiltration/inflow. Station operating normally.
114	Davidson Branch PS	09/13/20	09/13/20	10.83 hours	0.731	2.01	Rainfall	Infiltration/inflow. Station operating normally.
138	Sunliner PS	09/13/20	09/13/20	0.5 hours	0.02	2.74	Rainfall	Infiltration/inflow. Station operating normally.