

# Monthly Overflow Report

Date Range: September, 2022

Central WWTP NPDES# TN 0020575

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station
000	08112076	09/01/22	3 hours		Grit/Debris	1526 Arthur Ave - Cleaned Line
		09/01/22	0.0001	Dry Weather Release	Contained, did not reach water	28th Avenue SPS
000	08209312	09/04/22	3 hours		Air Relief Valve	1423 2nd Ave N - Repaired ARV
		09/04/22	0.0015	Dry Weather Release	Contained, did not reach water	Central WWTP
000	08210036	09/06/22	17.5 hours		Air Relief Valve	211 N 1st St - Repaired ARV
		09/07/22	1	Dry Weather Overflow	Cumberland River	Central WWTP
000	13409008	09/10/22	8 hours	0.19	Grit/Debris	3949 Atkins Dr - Cleaned Line
		09/10/22	0.001	Wet Weather Overflow	Seven Mile Creek	Browns Creek SPS
000	09314033	09/12/22	1 hours	0.01	Grit/Debris	809 Division St - Cleaned Line
		09/12/22	0.0001	Wet Weather Overflow	Cumberland River	Central WWTP
000	07114020	09/23/22	2 hours		Grit/Debris	2 Fern Ave - Cleaned Line
		09/23/22	0.00005	Dry Weather Release	Contained, did not reach water	Central WWTP
000	16410071	09/23/22	1 hours	0.01	Grit/Debris	3721 Mountain Springs Rd - Cleaned Line
		09/24/22	0.00001	Wet Weather Release	Contained, did not reach water	Summerfield SPS
000	15005088	09/24/22	2 hours	0.02	Grit/Debris	1520 Overcreek Dr - Cleaned Line
		09/24/22	0.00001	Wet Weather Release	Contained, did not reach water	Smith Springs SPS
168	Scales Farmstead SPS	09/15/22	0.5 hours	0.00	Mechanical	Pump failure.
		09/15/22	0.01	Dry Weather Release	Contained, did not reach water	Scales Farmstead SPS

Monthly Totals: # of Events and Gallons					12 Month Rolling Totals: # of Events and Gallons						
<b>Dry Weather Releases:</b>	4	11,650	<b>Wet Weather Releases:</b>	2	20	<b>Dry Weather Releases:</b>	33	14,050	<b>Wet Weather Releases:</b>	44	623,250
<b>Dry Weather Overflows:</b>	1	1,000,000	<b>Wet Weather Overflows:</b>	2	1,100	<b>Dry Weather Overflows:</b>	17	1,003,040	<b>Wet Weather Overflows:</b>	237	882,961,730

# Monthly Overflow Report

Date Range: September, 2022

Dry Creek WWTP NPDES# TN0020648

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

## Sanitary Sewer Overflows and Releases

000	05303062	09/15/22	17 hours		Grease	505 15th St - Cleaned Line
		09/16/22	0.00001	Dry Weather Release	Contained, did not reach water	Old Hickory SPS
<b>Monthly Totals: # of Events and Gallons</b>				<b>12 Month Rolling Totals: # of Events and Gallons</b>		
<b>Dry Weather Releases:</b>	1	10	<b>Wet Weather Releases:</b>	0	0	<b>Dry Weather Releases:</b> 2 510 <b>Wet Weather Releases:</b> 1 10
<b>Dry Weather Overflows:</b>	0	0	<b>Wet Weather Overflows:</b>	0	0	<b>Dry Weather Overflows:</b> 3 1,100 <b>Wet Weather Overflows:</b> 32 9,958,000

# Monthly Overflow Report

Date Range: September, 2022

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Location	Start Date	Duration (hrs)	Rainfall	Overflow Cause	Remarks
		End Date	Volume (mg)	Overflow Type	Receiving Stream	Downstream Pump Station

## Sanitary Sewer Overflows and Releases

000	10507035	09/14/22	1 hours		Grit/Debris	557 Hamilton Ave - Cleaned Line	
		09/14/22	0.00001	Dry Weather Release	Contained, did not reach water	Central WWTP	
145	Joelton PS	09/03/22	1 hours	1.97	Rainfall	Infiltration/inflow. Station operating normaly.	
		09/03/22	0.01	Wet Weather Overflow	Tributary to Long Creek	Joelton SPS	
<b>Monthly Totals: # of Events and Gallons</b>				<b>12 Month Rolling Totals: # of Events and Gallons</b>			
<b>Dry Weather Releases:</b>	1	10	<b>Wet Weather Releases:</b>	0	0	<b>Dry Weather Releases:</b> 5 230 <b>Wet Weather Releases:</b> 17 1,302,580	
<b>Dry Weather Overflows:</b>	0	0	<b>Wet Weather Overflows:</b>	1	10,000	<b>Dry Weather Overflows:</b> 4 110,120 <b>Wet Weather Overflows:</b> 46 15,751,100	