

# Monthly Overflow Report

Date Range: November, 2019

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	14701047	11/08/19	11/08/19	2.5 hours	0.001		Grit/Debris	321 Lynn Dr - Cleaned Line
000	16413060	11/11/19	11/12/19	24 hours	0.001	0.41	Grit/Debris	3820 Asheford Tc - Cleaned Line
000	16413056	11/13/19	11/13/19	9 hours	0.001		Grit/Debris	3826 Asheford Trace - Cleaned Line
000	16004025	11/18/19	11/18/19	2 hours	0.0001		Grease	5224 Trousdale Dr - Cleaned Line
000	14711044	11/21/19	11/21/19	0.5 hours	0.0001		Grit/Debris	521 Northcrest Dr - Cleaned Line
000	09514012	11/22/19	11/22/19	2.5 hours	0.00001	1.35	Grit/Debris	1050 Acorn Dr - Cleaned Line
000	09206135	11/27/19	11/27/19	3 hours	0.00001	1.32	Grit/Debris	2821 Clifton Ave - Cleaned Line
000	11907146	11/27/19	11/27/19	17 hours	0.001	1.50	Rainfall	431 E Thompson Ln
000	11907146	11/30/19	12/01/19	24 hours	0.001	1.13	Rainfall	431 E Thompson Ln
125	Hopedale PS	11/30/19	11/30/19	0.25 hours	0.001	1.62	Rainfall	Infiltration/inflow. Station at rated capacity.
131	Hurricane Creek PS	11/30/19	12/01/19	3.25 hours	0.2	2.08	Rainfall	Infiltration/inflow. Station at rated capacity.
186	Mt. View SPS	11/30/19	12/01/19	4.5 hours	0.001	2.08	Rainfall	Infiltration/inflow. Station at rated capacity.
188	South Oak Hill PS	11/30/19	12/01/19	24.25 hours	1.4	1.11	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	11/27/19	11/27/19	10 hours	0.193	1.51	Rainfall	Infiltration/inflow. Station operating normally.
374	Foster Ave	11/27/19	11/27/19	17 hours	0.001	1.50	Rainfall	2803 Foster Ave

---

# Monthly Overflow Report

Date Range: November, 2019

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
110	Loves Branch PS	11/22/19	11/22/19	3.58 hours	0.134	1.61	Rainfall	Infiltration/inflow. Station at rated capacity.
384	501 Bismark Dr.	11/27/19	11/27/19	17 hours	0.001	1.32	Rainfall	501 Bismark Dr

# Monthly Overflow Report

Date Range: November, 2019

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	12915024	11/24/19	11/24/19	2 hours	0.0001	1.65	Grit/Debris	255 Cana Dr - Cleaned Line
114	Davidson Branch PS	11/22/19	11/22/19	10.83 hours	0.821	1.52	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	11/26/19	11/27/19	17.5 hours	1.252	1.54	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	11/30/19	12/01/19	2.83 hours	0.045	0.63	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	11/27/19	11/27/19	7.75 hours	0.05	1.71	Rainfall	Infiltration/inflow.