

Monthly Overflow Report

Date Range: October, 2019

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	10612019	10/04/19	10/04/19	2.5 hours	0.0001		Grit/Debris	895 Murfreesboro Pk - Cleaned Line
000	07109059	10/11/19	10/12/19	5 hours	0.00001	0.63	Grit/Debris	301 Great Circle Rd - Cleaned Line
000	WLS052F024	10/14/19	10/14/19	1 hours	0.00001		Roots	4845 Catskill Dr - Cleaned Line
000	16102001	10/14/19	10/14/19	5 hours	0.001		Grit/Debris	5007 Meta Dr - Cleaned Line
000	16004017	10/17/19	10/18/19	14 hours	0.001		Roots	5242 Trousdale Dr - Cleaned Line
000	18003020	10/24/19	10/25/19	24 hours	0.001	0.71	Grit/Debris	6716 Holt Rd - Cleaned Line
000	16407007	10/27/19	10/27/19	3 hours	0.0001		Grease	216 Grovedale Trace - Cleaned Line
000	00216001	10/31/19	10/31/19	7 hours	0.001	1.86	Grease	101 East End Rd - Cleaned FM (Grease & Vandalism)
140	28th Avenue PS / Centennial	10/07/19	10/07/19	3.67 hours	0.397	3.44	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	10/31/19	10/31/19	4 hours	0.008	1.75	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: October, 2019

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
106	Vandiver PS	10/07/19	10/07/19	0.33 hours	0.009	3.51	Rainfall	Infiltration/inflow. Station at rated capacity.
108	River Retreat	10/07/19	10/07/19	2.5 hours	0.2	3.18	Controller	One force main was closed for repairs.
110	Loves Branch PS	10/07/19	10/07/19	1.25 hours	0.115	3.18	Rainfall	Infiltration/inflow. Station at rated capacity.
166	Brandywine Point PS	10/28/19	10/28/19	0.5 hours	0.02	0.00	Excessive Flow	Contractor drained swimming pool to sewer.

Monthly Overflow Report

Date Range: October, 2019

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	07008054	10/05/19	10/05/19	6 hours	0.0001		Air Relief Valve	832 Youngs Ln - Closed AR valve
000	12915024	10/08/19	10/08/19	2 hours	0.001		Roots	255 Cana Cir - Cleaned Line
000	14512003	10/25/19	10/26/19	4 hours	0.0001	2.04	Force Main	5063 Lakeview Dr - Repaired Line
000	10402034	10/28/19	10/28/19	1 hours	0.001		Grit/Debris	211 31st Ave N - Cleaned Line
114	Davidson Branch PS	10/07/19	10/07/19	2.5 hours	0.072	3.07	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	10/26/19	10/26/19	8.5 hours	0.391	1.75	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	10/30/19	10/31/19	16.83 hours	0.745	2.16	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	10/07/19	10/07/19	5 hours	0.02	4.13	Rainfall	Infiltration/inflow. Station at rated capacity.